

**NIT NO. ITPS/UNIT 3 & 4/ 20-21/116 DT. 06/01/2021
SUPPLY OF EROSION PROTECTION SHIELDS FOR BOILER
PRESSURE PARTS TUBES – UNIT 3 & 4 (TWO PARTS).**

Corrigendum - 01

SPECIFICATION AMENDMENT

In addition to the specification mentioned in the tender document vide NIT NO. ITPS/UNIT 3 & 4/ 20-21/116 DTD. 06/01/2021, all protection shields should be of Seamless type.