



ODISHA POWER GENERATION CORPORATION LIMITED
IB THERMAL POWER STATION
At/PO: BANHARPALI, DIST: JHARSUGUDA – 768 234
(ODISHA) TELEFAX: (06645) 222288

1st CORRIGENDUM NIT No. ITPS/ Pur./23-24/08 Dated:02/06/2023

1) Technical Details:

1. **DRC Bend 100 NB, 90 Degree.**

S.No	Description	Specification
1	ID and OD of Bends	Ceramic ID 103 ± 2 mm, MS OD 165 ± 2 mm, Radius of Bend 300 mm, 90 degree.
2	Casing and DRC lining Thickness	Casing Thickness – 4.85 ± 0.5 mm. DRC lining thickness – 27.65 ± 1 mm.
3	End connection details (Fixed and Matching Flange ID, OD,PCD etc)	Fixed Flange: ID 169 mm, OD 280 mm, Thickness 12 mm, No of Holes 8 mm, Hole Dia.18 mm, PCD 235 mm. Matching Flange: ID 100 mm, OD 280 mm, Thickness 12 mm, No of Holes 8 mm, Hole Dia. 18 mm, PCD 235 mm, Qty 2 - No's Retainer ring: ID 100 mm, OD 165 mm, Thickness 5 mm
4	Straight length in bends, if any.	One straight length at each corner of bend.

2. **DRC Bend 150 NB, 90 Degree.**

S.No	Description	Specification
1	ID and OD of Bends	Ceramic ID 150 ± 2 mm, MS OD 193.7 ± 2 mm, Radius of Bend 450 mm, 90 degree.
2	Casing and DRC lining Thickness	Casing Thickness – 5 ± 0.5 mm. DRC lining thickness – 16.5 ± 1 mm.
3	End connection details (Fixed and Matching Flange ID, OD ,PCD etc)	Fixed Flange: ID 197 mm, OD 305 mm, Thickness 14 mm, No of Holes 8 mm, Hole Dia.18 mm, PCD 260 mm. Matching Flange: ID 150 mm, OD 305 mm, Thickness 14 mm, No of Holes 8 mm, Hole Dia. 18 mm, PCD 260 mm, Qty - 2 No's Retainer ring: ID 150 mm, OD 193 mm, Thickness 5 mm
4	Straight length in bends, if any.	One straight length at each corner of bend.

SAFE & CLEAN POWER IS OUR COMMITMENT



ODISHA POWER GENERATION CORPORATION LIMITED
IB THERMAL POWER STATION
At/PO: BANHARPALI, DIST: JHARSUGUDA – 768 234
(ODISHA) TELEFAX: (06645) 222288

- 2) The tender dates for the work of our NIT No. ITPS/ Pur./23-24/08 Dated:02/06/2023 is extended as follows:
- a) Date of sale: Up to 15:00 Hrs. of 03/07/2023
 - b) Date of receipt/submission: Up to 15:00 Hrs. of 03/07/2023
 - c) Date of Opening: 15:30 Hrs. onwards on 03/07/2023

N.B: All other stipulations/conditions of NIT No. ITPS/ Pur./23-24/08 Dated:02/06/2023 shall remain unaltered. This corrigendum can be seen from website www.opgc.co.in

Sd/-
GM-SCM

SAFE & CLEAN POWER IS OUR COMMITMENT