



**BGR ENERGY SYSTEMS LIMITED
POWER PROJECTS DIVISION**

Sheet 1 of 1

**GEOTECHNICAL INVESTIGATION REPORT
VOLUME-I
DOCUMENT NO: GID-208-CV-DOC-3015**

Rev-3

**2x660MW IB THERMAL POWER STATION UNIT-3 & 4, OPGCL,
BANHARPALLI, DIST. – JHARSUGUDA, ODISHA.**

**GEOTECHNICAL INVESTIGATION REPORT
VOLUME-I FOR BTG AREA
GID-208-CV-DOC-3015**



**BGR ENERGY SYSTEMS LIMITED
POWER PROJECTS DIVISION
443, ANNA SALAI
TEYNAMPET, CHENNAI - 600018
PH : 044 24326171, FAX : 044 24315678**

DATE	REVISIONS	PREPARED BY	CHECKED BY	APPROVED BY
09-09-2015	Revised ERT test locations as executed in BH layout plan-R3	GM	SPR	HOD
03-05-2014	Revised as per OPGCL/DCPL comments dt: 21-12-2013 –R2	Soil Engg	GM/SPR	HOD
02-12-2013	Revised as per client comments dt: 21.11.2013 – R1	BVG	GM/SPR	HOD
23-10-2013	For approval – R0	BVG	GM/SPR	HOD

**2x660MW IB THERMAL POWER STATION UNIT-3 & 4, OPGCL,
BANHARPALLI, DIST. – JHARSUGUDA, ODISHA.**

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

OWNER: ODISHA POWER GRID CORPORATION LIMITED, ODISHA

CLIENT: BGR ENERGY SYSTEM LTD, CHENNAI



SOIL ENGINEERING CONSULTANTS

B-310, ANSAL CHAMBERS-I
BHIKAIJI CAMA PLACE, NEW DELHI-110 066
PH: 011 26175994, 26104443 FAX: 011 26104443
E Mail –soilengg@gmail.com

OCTOBER-2013

18-10-2013	RAJESH	PS RAO	RANGA RAO
DATE	PREPARED BY	CHECKED BY	APPROVED BY

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

CONTENTS

S.NO	CHAPTER	PAGE NO.
1	INTRODUCTION	1
2	SCOPE OF WORK	1
3	FIELD WORK <ul style="list-style-type: none"> • Boring • Standard Penetration Test • Collection of Samples • Water Table 	2 - 3
4	LABORATORY TESTS	4
5	SOIL & ROCK CHARACTERISTICS <ul style="list-style-type: none"> • Transformer Yard Area • Power Block Area • Boiler Area • Storage Tank and PH Area • ESP Area • Chimney Area • Switch Yard 	4 - 13
6	DESIGN CRITERIA	13
7	COMPUTATIONS	15 - 32
8	RECOMMENDATION	33 - 35
9	ROCK TEST RESULTS (ANNEXURE-I)	36 - 38
10	FREE SWELL INDEX (ANNEXURE-II)	39

Project: 2x660MW IB TPS UNIT-3 & 4, OPGCL, BANHARPALLI,

DIST. – JHARSUGUDA, ODISHA



PROJECT NO: 1988

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

11	BORELOGS	
	• Transformer Yard Area	B1-1/2 to BH 2-2/2 & B34-1/2 to BH 34-2/2
	• Power Block Area	B3-1/3 to BH 5-3/3
	• Boiler Area	B6-1/3 to BH 9-3/3 & B11-1/3 to BH 11-3/3
	• Storage Tank and PH Area	B10-1/3 to BH 10-3/3
	• ESP Area	B12-1/3 to BH 14-3/3
	• Chimney Area	B16-1/3 to BH 16-3/3
	• Switch Yard Area	B32-1/2 to BH 32-2/2
12	SOIL PROFILES	Profile A to Profile F
13	Grain Size Analysis (GSD)CURVES	GSD -1 to GSD – 11 & 32
14	DIRECT SHEAR TEST(DST) CURVES	DS 1 & DS 2
15	TRI AXIAL TEST CURVES	T1 to T4
16	CONSOLIDATION CURVES	C1 – C6

1.0 INTRODUCTION

M/s BGR Energy Systems Limited has awarded the work of Soil Investigation works for the proposed 2X660 MW Unit # 3 & 4 – IB Thermal Power Project, Odisha to M/s Soil Engineering Consultants, New Delhi. This Volume I report presents the details of Geotechnical investigations carried out at BTG Area and data obtained from various field and laboratory tests, their presentation in graphical form, their computation, compilation, analysis and suitable recommendation made as regards to type of foundations to be adopted for the Main Plant structures based on BH 1 to BH 14, BH 16, BH 32 and BH 34.

2.0 SCOPE OF WORK

- a) Drilling bore holes upto the maximum depth of 25.0 m by Shell and auger method or up to refusal. Beyond refusal strata drilling using Hydraulic Feed Drilling Machine with double tube core barrel and Nx size diamond drilling bits upto specified depth as per IS code of practice and as per the direction of the Engineer-in-Charge.
- b) Conducting Standard Penetration tests in the bore holes at regular intervals of 1.50m or change of strata as per IS Code of Practice.
- c) Collecting Disturbed / Undisturbed soil samples from the bore holes at regular intervals or change of strata as per IS Code of Practice.
- d) Recording of water table level in the bore holes after completion of borehole.
- e) Conducting all the necessary laboratory tests on the samples collected.
- f) Preparation of report summarizing the details of soil classification, analysis of test data, type of foundation etc.

3.0 FIELD WORK

3.1 Boring

Bore holes of 150 mm dia. were drilled by Shell and auger method upto the refusal depth as per IS code of practice and the directions of the Engineer in charge. Refusal was obtained in all the boreholes at varying depths. In refusal strata rotary drilling was resorted by using Hydraulic feed drilling machine with double tube core barrel and Nx size diamond bits as per IS code of practice. The details about the depth of bore holes, co ordinates and RL's are given in Table 1 and also in borelogs.

3.2 Standard Penetration Test (SPT)

Standard Penetration tests were conducted at every 1.50m intervals and every change of strata or wherever possible. The tests were performed by driving into the soil (bore holes cleaned of any loose material) a standard split spoon sampler with the help of a standard hammer with a free fall of 75 cms on a driving head as described in IS: 2131. This head was attached to "A" drill rod to the other end of which the sampler was fitted. The number of blows needed to penetrate the first, second and third stages (each of 15 cms) depth of the sampler length, were noted. The number of blows (N- value) as given in the bore hole data sheets is the numerical sum of blows counted during the second & third stage only i.e. for a depth of 30 cms.

3.3 Collection of Samples

Both Disturbed and Undisturbed soil samples, Rock Core Samples were collected from the bore holes.

3.4 Recording of water table

Water table was met in all boreholes at varying depths at the time of Soil investigation. The details are given in the respective bore logs and also at **Table 1** below.

Location	BH No.	Depth of BH (m)	RL (m)	Co-ordinates		water table (m)
				East	South	
Transformer Yard	1	15.0	203.000	1394	1316	2.60
	2	15.0	201.800	1495	1316	2.80
	34	15.0	199.500	1432	1196	0.40
Power House Block	3	25.0	202.800	1450	1369	2.40
	4	25.0	201.128	1315	1369	0.40
	5	25.0	199.744	1237	1369	0.40
Boiler	6	25.0	200.125	1275	1422	0.50
	7	25.0	202.100	1375	1422	2.45
	8	25.0	202.440	1453	1447	2.80
	9	25.0	201.900	1480	1497	2.65
	11	25.0	199.631	1275	1497	1.10
Switch Yard	32	15.0	199.436	1358	1072	0.80
Storage Tank & P/H	10	25.0	200.200	1385	1497	0.90
ESP	12	20.0	199.400	1295	1552	0.75
	13	20.0	199.50	1434	1639	1.10
	14	20.0	199.700	1468	1556	0.60
Chimney	16	25.0	199.700	1396	1711	1.20

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

4.0 LABORATORY TESTS

A visual and discrete examination of all the soil / rock samples collected was carried out for deciding the number and type of tests to be tested from each bore hole. Based on the strata met at site the following tests were conducted on samples to classify them and to evaluate their index and Engineering properties.

SOIL SAMPLES

- a) Grain size distribution as per IS: 2720(Part IV).
- b) Hydrometer Analysis as per IS: 2720(Part IV).
- c) Liquid and plastic limits as per IS: 2720(Part V).
- d) Specific gravity as per IS : 2720(Part III).
- e) Bulk density and dry density as per IS : 2720(Part II).
- f) Moisture content as per IS : 2720(Part II).
- g) Direct shear test as per IS : 2720(Part XIII)
- h) Consolidated Undrained Shear Test as per IS : 2720(Part XII)
- i) Consolidation as per IS : 2720(Part XV)

ROCK SAMPLES

The rock samples on saturation were dissolved. Only Density tests were performed on the samples. The results are given at Annexure I.

5.0 SOIL & ROCK CHARACTERISTICS

Transformer Yard

At this location Three Boreholes (BH 1,BH 2 and BH 34) were drilled upto 15m depth. The Boreholes were advanced by Shell and auger method upto the refusal depth. While advancing the bore holes SPT tests were conducted at regular intervals of 1.5m depth and representative samples were collected and analyzed for soil classification. From the soil classification it revealed that the strata consists of Filled up soil upto varying depths of 0.40m to 1.20 depth followed by Silty clay of High Plasticity (CH) upto the rocky strata depth. Rocky strata was obtained at varying depths of 4.50m to 5.0m depth. In rocky strata the boreholes were

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

advanced by Hydraulic feed rotary drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as highly weathered disintegrated rock / Highly weathered and fractured rock. The details of classification, Core recovery and RQD are as given below:

BH 1

Rocky strata was observed from 4.50m depth. The overburden strata is classified as Filled up soil upto 1.20m depth followed by Silty clay of High Plasticity (CH). The rocky strata is classified as Highly weathered and highly fractured yellowish color Sandstone/siltstone upto 6.0m depth followed by highly weathered disintegrated rock upto 7.50m depth. Below 7.50m depth the strata is classified as Highly weathered and fractured Shale upto the depth drilled. The Core recovery is around 15% upto 6.0m depth. From 6.0m to 7.50m depth the core recovery is Nil. Below 7.50m depth the core recovery is varying from 40% to 85%. RQD is Nil upto 7.50m depth and from 12.0m to 13.50m depth. At other depths RQd is varying from 34% to 67%.

BH 2

Rocky strata was observed from 5.00m depth. The overburden strata is classified as Filled up soil upto 0.40m depth followed by Silty clay of High Plasticity (CH). The rocky strata is classified as Highly weathered and highly fractured yellowish color Sandstone/siltstone upto 10.50m depth followed by highly weathered and fractured grayish color Shale upto the depth drilled. Core recovery is varying from 35% to 72%. RQD is varying from 8% to 59% upto 13.50m depth. Below 13.50m depth RQD is Nil upto the depth drilled.

BH 34

Rocky strata was observed from 7.00m depth. The overburden strata is classified as Filled up soil upto 1.50m depth followed by non-plastic Silty sand with gravel (SM) upto 3.0m depth. Below 3.0m depth the strata consists of Silty clay mixed with Sand (CI-CH) upto the rocky strata depth. In rocky strata the borehole was advanced by Hydraulic feed rotary

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as Highly weathered and fractured Silt Stone (Core recovery 20% to 40%). RQD is varying from 9% to 16% except from 7.0m to 7.50m depth, from 10.50m to 12.0m depth and from 13.50m to 15.0m depth wherein RQD is Nil.

Power House Block

At this location Three Boreholes (BH 3 to BH 5) were drilled upto 25m depth. The Boreholes were advanced by Shell and auger method upto the refusal depth. While advancing the bore holes SPT tests were conducted at regular intervals of 1.5m depth and representative samples were collected and analyzed for soil classification. From the soil classification it revealed that the strata consists of Filled up soil upto varying depth of 0.40m to 0.70m depth followed by non-plastic Silty sand with gravel (SM)/ Silty clay of Medium Plasticity (CI) upto the rocky strata depth. Rocky strata was obtained at varying depths of 4.50m to 8.0m depth. In rocky strata the boreholes were advanced by Hydraulic feed rotary drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as highly weathered disintegrated rock / Highly weathered and fractured rock. The details of classification, Core recovery and RQD are as given below:

BH 3

Rocky strata was observed from 4.50m depth. The overburden strata is classified as Filled up soil upto 0.70m depth followed by non-plastic Silty sand with gravel (SM)/ Silty clay of Medium Plasticity (CI). The rocky strata is classified as Highly weathered and highly fractured / fractured yellowish color Sandstone/siltstone upto the depth drilled with core recovery varying from 10% to 80% except from 15.0m to 19.50m depth wherein the strata is classified as Highly weathered disintegrated rock with no core recovery.

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

RQD is Nil upto 7.50m depth, from 15.0m to 21.0m depth and from 24.0m to 25.0m depth. From 7.50m to 15.50m depth RQD is varying from 8% to 40%. From 21.0m to 24.0m depth RQD is varying from 7% to 25%.

BH 4

Rocky strata was observed from 6.00m depth. The overburden strata is classified as Filled up soil upto 0.50m depth followed by non-plastic Silty Sand with Gravel/Silty sand with gravel (SM). The rocky strata is classified as Highly weathered disintegrated rock with no core recovery upto 21.0m depth except from 6.0m to 7.50m depth and from 12.0m to 13.50m depth wherein the strata is classified as Highly weathered and highly fractured yellowish color Sandstone/siltstone with core recovery around 3%. Below 21.0m depth the strata is classified as Moderately weathered and fractured yellowish to grayish color Sand stone with Core recovery varying from 74% to 90%. RQD is Nil upto 21.0m depth and below 21.0m depth RQD is varying from 62% to 78% upto the depth drilled.

BH 5

Rocky strata was observed from 8.00m depth. The overburden strata is classified as Filled up soil upto 0.50m depth followed by non-plastic Silty sand with gravel (SM). The rocky strata is classified as Highly weathered disintegrated rock with no core recovery upto 21.0m depth except from 6.0m to 7.50m depth and from 12.0m to 13.50m depth wherein the strata is classified as Highly weathered and highly fractured yellowish color Sandstone/siltstone with core recovery around 3%. Below 21.0m depth the strata is classified as Moderately weathered and fractured yellowish to grayish color Sand stone with Core recovery varying from 74% to 90%. RQD is Nil upto 21.0m depth and below 21.0m depth RQD is varying from 62% to 78% upto the depth drilled.

Boiler Area

Five bore holes (BH6, BH 7, BH 8, BH 9 and BH 11) were drilled at the proposed Boiler Area upto 25m depth. The Boreholes were advanced by Shell and auger method upto the refusal depth. While advancing the bore holes SPT tests were conducted at regular intervals of 1.5m depth and

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

representative samples were collected and analyzed for soil classification. From the soil classification it revealed that the strata consists of filled up soil upto varying depths of 0.30m to 0.70m followed by non-plastic yellowish color Sandy Silt with gravel/Silty sand with gravel (SM) and Silty clay mixed with Sand (CI). Rocky strata was obtained at varying depths of 3.50m to 8.50m. In rocky strata the boreholes were advanced by Hydraulic feed rotary drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as highly weathered disintegrated rock followed by highly weathered fractured rock. The details of each bore hole are as given below:

BH 6

Rocky strata was obtained at a depth of 8.50m below ground surface. The overburden strata is classified as Filled up soil upto 0.40m depth followed by Sandy silt with gravel(sSM-ML)/Silty sand with Gravel (SM). From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore hole the refusal strata is classified as highly weathered and fractured Sand stone upto 12.0m depth and from 21m to 24.0m depth. From 12.0m to 21.0m depth the strata is classified as highly weathered disintegrated rock with no core recovery and RQD. From 24.0m to 25m depth the strata is classified as highly weathered and highly fractured Shale. From 8.50m to 12.0m depth the Core recovery is varying from 23% to 34%. From 12.0m to 21m depth the core recovery is Nil. From 21.0m to 25.0m depth the core recovery is varying from 42% to 46%. RQD is Nil except from 9.0m to 12.0m depth wherein RQD is around 23% and from 21.0m to 24.0m depth wherein RQD is varying from 10% to 18%.

BH 7

Rocky strata was obtained at a depth of 4.50m below ground surface. The overburden strata is classified as Filled up soil upto 0.50m depth followed by Silty Clay mixed with Sand (CI). From the samples of the core recovery,

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

drill log, representative samples, wash samples and return of drilled water from bore hole the refusal strata is classified as highly weathered and highly fractured Sand stone upto 15.0m depth and from 18.0m to 21.0m depth. From 15.0m to 18.0m depth the strata is classified as highly weathered disintegrated rock with no core recovery and RQD. From 21.0m to 25m depth the strata is classified as highly weathered and fractured Sand stone. The core recovery is varying from 8% to 71% except from 15.0m to 18.0m depth wherein the core recovery is Nil. RQD is Nil except from 4.50m to 6.0m (RQD around 9%) , from 18.0m to 21.m (RQD varying from 14% to 19% and from 21.0m to 25m depth (RQD varying from 45% to 69%).)

BH 8

Rocky strata was obtained at a depth of 3.50m below ground surface. The overburden strata is classified as filled up soil upto 0.70m depth followed by Silty Clay mixed with Sand (CI). From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore hole the refusal strata is classified as alternate layers of highly weathered and highly fractured Sand stone (Core recovery varying from 10% to 41%) and Highly weathered disintegrated rock (Nil Core recovery) upto 13.50m depth. From 13.50m to 18.0m depth and from 21.0m to 25.0m depth the strata is classified as highly weathered and fractured Sandstone/siltstone. From 18.0m to 21.0m depth the strata is classified as Highly weathered and fractured Shale. Below 13.50m depth the core recovery is varying from 22% to 74% and RQD is varying from 10% to 61%.

BH 9

Rocky strata was obtained at a depth of 6.00m below ground surface. The overburden strata is classified as filled up soil upto 0.50m depth followed by Sandy silt with gravel(SM-ML)/Silty Clay of medium Plasticity(CI). From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore hole the refusal strata is classified as Highly weathered disintegrated rock (Nil Core recovery) upto 10.50m depth followed by highly weathered and fractured

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

Sandstone/siltstone upto 22.50m depth. Below 22.50m depth the strata is classified as Highly weathered fractured Shale upto the depth drilled. The core recovery is varying from 10% to 72%. RQD is Nil upto 19.50m depth and below 19.50m depth RQD is varying from 12% to 55%.

BH 11

Rocky strata was obtained at a depth of 3.50m below ground surface. The overburden strata is classified as filled up soil upto 0.30m depth followed by Silty clay of Medium Plasticity (CI). From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore hole the refusal strata is classified as highly weathered and fractured Sand stone upto 16.50m depth and from 19.50m to 22.50m depth. From 16.50m to 19.50m depth the strata is classified as highly weathered disintegrated rock with no core recovery and RQD. From 22.50m to 25m depth the strata is classified as highly weathered and highly fractured Shale. Core recovery is varying from 12% to 69% except from 16.5m to 19.50m depth wherein the core recovery is Nil. RQD is varying from 7% to 35% except from 3.50m to 6.0m and from 16.50m to 21.0m depth wherein RQD is Nil.

The rock samples on saturation were dissolved. Only Density tests were performed on the samples.

Storage Tank & Pump House

At this location One Borehole (BH 10) was drilled upto 25m depth. The Borehole was advanced by Shell and auger method upto the refusal depth. While advancing the bore hole SPT tests were conducted at regular intervals of 1.5m depth and representative samples were collected and analyzed for soil classification. From the soil classification it revealed that the strata consists of Filled up soil upto 0.75m depth followed by Silty clay mixed with Sand (CI) upto 4.0m depth. Below 4.0m depth the strata consists of non-plastic Silty sand with gravel (SM) upto the rocky strata depth. Rocky strata was obtained at 6.50m depth. In rocky strata the borehole was advanced by Hydraulic feed rotary drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the

core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as alternate layers highly weathered disintegrated rock (Core recovery Nil) and Highly weathered and fractured Sand Stone (Core recovery 10% to 29%) of varying thickness. RQD is Nil except from 15.0m to 16.50m depth wherein RQD is around 23%.

ESP

At this location Three Boreholes (BH 12 to BH 14) were drilled upto 20m depth. The Boreholes were advanced by Shell and auger method upto the refusal depth. While advancing the bore holes SPT tests were conducted at regular intervals of 1.5m depth and representative samples were collected and analyzed for soil classification. From the soil classification it revealed that the strata consists of Filled up soil upto varying depth of 0.50m to 3.0m depth followed by Silty clay of Medium Plasticity (CI) upto the rocky strata depth. Rocky strata was obtained at varying depths of 3.50m to 6.0m depth. In rocky strata the boreholes were advanced by Hydraulic feed rotary drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as highly weathered and fractured sand stone / Silt stone. The details of classification, Core recovery and RQD are as given below:

BH 12

Rocky strata was observed from 3.50m depth. The overburden strata is classified as Filled up soil upto 0.50m depth followed by Silty clay of Medium Plasticity (CI). The rocky strata is classified as Highly weathered and highly fractured / fractured yellowish color Sandstone/ Silt Stone upto the depth drilled with core recovery varying from 30% to 54%. RQD is varying from 7% to 54% except from 3.50m to 4.50m depth and from 12.0m to 13.50m depth.

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

BH 13

Rocky strata was observed from 6.00m depth. The rocky strata is classified as Highly weathered and fractured yellowish color Sandstone/ Silt Stone upto 12.0m depth followed by Highly weathered disintegrated silt stone upto the depth drilled. Core recovery is varying from 34% to 61% upto 12.0m depth and below 12.0m depth the core recovery is Nil. RQD is varying from 10% to 33% upto 12.0m depth and below 12.0m depth RQD is Nil upto the depth drilled.

BH 14

Rocky strata was observed from 4.50m depth. The overburden strata is classified as Filled up soil upto 3.0m depth followed by Silty clay of Medium Plasticity (CI). The rocky strata is classified as Highly weathered and highly fractured / fractured yellowish color Sandstone/ Silt Stone upto the depth drilled with core recovery varying from 15% to 57%. RQD is varying from 18% to 53% except from 4.50m to 9.0m depth and from 12.0m to 13.50m depth.

Chimney

At this location One Borehole (BH 16) was drilled upto 25m depth. The Borehole was advanced by Shell and auger method upto the refusal depth. While advancing the bore hole SPT tests were conducted at regular intervals of 1.5m depth and representative samples were collected and analyzed for soil classification. From the soil classification it revealed that the strata consists of Filled up soil upto 3.0m depth followed by Silty clay of Medium Plasticity (CI) upto 8.50m depth. Below 8.50m depth the strata consists of Sandy Silt (SM-ML) upto the rocky strata depth. Rocky strata was obtained at 9.50m depth. In rocky strata the borehole was advanced by Hydraulic feed rotary drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as Highly weathered and fractured Silt Stone / Sand stone / Highly weathered disintegrated rock. Core recovery is varying from 10% to 22% except from 10.50m to 13.50m depth,

and 21.0m to 22.50m depth wherein the Core recovery is Nil. RQD is Nil except from 13.50m to 15.0m depth and from 16.50m to 18.0m depth wherein the RQD is around 17% to 18%.

Switch Yard

At this location One Borehole (BH 32) was drilled upto 15m depth. The Boreholes were advanced by Shell and auger method upto the refusal depth. While advancing the bore holes SPT tests were conducted at regular intervals of 1.5m depth and representative samples were collected and analyzed for soil classification. From the soil classification it revealed that the strata consists of Filled up soil upto 1.30m depth followed by Silty Clay mixed with Sand (CH) upto the rocky strata depth. Rocky strata was obtained at varying depths of 4.50m depth. In rocky strata the boreholes were advanced by Hydraulic feed rotary drilling machine using Nx size Diamond Core bit upto the specified depth. From the samples of the core recovery, drill log, representative samples, wash samples and return of drilled water from bore holes the refusal strata is classified as highly weathered and fractured Sand Stone. Core recovery is varying from 17% to 92%. RQD is varying from 12% to 83% except from 7.50m to 9.0m depth wherein RQD is Nil.

6.0 DESIGN CRITERIA

As the refusal stratum has been encountered at shallow depths footing foundation has been analysed. The analysis is based on SPT & ϕ values as there is no core recovery or core recovery is less.

The water table was encountered at shallow depths. The water table was considered at ground level and accordingly correction factor has been considered as 0.50 for design purpose.

An allowable settlements of 25mm and 40mm has been considered for the analysis of footing foundation and raft foundation respectively.

6.1.1 Foundation resting on Non Plastic strata (Based on SPT & ϕ .)

a) Shear failure criteria

The safe bearing pressure from Shear failure criteria can be obtained, using the equation given below as per IS 6403- 1981.

$$Q_u = q (N_q - 1) S_q D_q I_q + 0.5 B \gamma N_y S_y D_y I_y W$$

Where,

B = Width of the footing in m

D_q, D_y = Depth factors

S_q, S_y = Shape factors

I_q, I_y = Inclination factors

N_q, N_y = Bearing capacity factor

q = Effective overburden pressure at foundation, in t/m²

W' = Water table correction factor

γ = Bulk unit wt. of foundation soil, in t/m³

General Shear Failure:

When $\phi > 36$

Local Shear Failure:

When $\phi < 28$

The values obtained are falling in between General Shear and Local Shear hence the values have interpolated between the above two as per IS 6403- 1981.

b) Settlements:

- a) Soil profiles are given for each borehole. The soil profile, which is likely to cause greater settlements, is to be considered for calculations.
- b) The imposed load at the foundation level is likely to compress the soil up to a depth of approximately equal to 1.5B below the foundations.
- c) The settlements can be calculated using Fig No 9 of IS: 8009 Part 1 & 2, 1976.

7.0 COMPUTATION

BH 1 & BH 2 (TRANSFORMER YARD)

Footing Foundation

Considering formation Level @ RL 199.50

Shear Failure Criteria

Case I

Df @ 196.50 B = 2.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) S_q d_q i_q + 0.5 B \gamma N_s s_s d_s i_s W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 39.608 \text{ t/m}^2 \quad Q_{safe} = 15.84 \text{ t/m}^2$$

Case II

Df @ 196.50 B = 3.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) S_q d_q i_q + 0.5 B \gamma N_s s_s d_s i_s W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 43.24 \text{ t/m}^2 \quad Q_{safe} = 17.29 \text{ t/m}^2$$

Case III

Df @ 196.50 B = 4.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) S_q d_q i_q + 0.5 B \gamma N_s s_s d_s i_s W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 46.296 \text{ t/m}^2 \quad Q_{safe} = 18.51 \text{ t/m}^2$$

Case IV

Df @ 195.50

B = 2.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 56.06 \text{ t/m}^2$$

$$Q_{safe} = 22.42 \text{ t/m}^2$$

Case V

Df @ 195.50

B = 3.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 59.70 \text{ t/m}^2$$

$$Q_{safe} = 23.88 \text{ t/m}^2$$

Case VI

Df @ 195.50

B = 4.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 62.756 \text{ t/m}^2$$

$$Q_{safe} = 25.10 \text{ t/m}^2$$

Settlement Criteria

Df (RL of Foundation depth in m)	@ RL 196.50			@ RL 195.50		
B (Width of foundation in m)	2	3	4	2	3	4
Settlement under footing with a load intensity of 10 t/m ² in dry condition (mm)	5	5	5	5	5	5
Settlement under footing with a load intensity of 10 t/m ² with water table correction(mm)	10	10	10	10	10	10
Settlement under footing with a load intensity of 10 t/m ² with water table and depth correction(mm)	8	8	9	7	8	8
Net safe bearing pressure for allowable settlement of 25 mm (t/m ²)	31.25	31.25	27.77	35.71	31.25	31.25

BH 3 to BH 5 (Power House Block)

Footing Foundation

Considering formation Level @ RL 199.500

Shear Failure Criteria

Case I

Df @ 194.50

B = 3.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) S_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 135.91 \text{ t/m}^2$$

$$Q_{safe} = 54.36 \text{ t/m}^2$$

Case II

Df @ 194.50

B = 5.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63, N_r = 30.22, S_q = 1.20, S_r = 0.80, W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 147.996 \text{ t/m}^2$$

$$Q_{safe} = 59.19 \text{ t/m}^2$$

Case III

Df @ 193.50 B = 3.00m

$\phi = 36, (\text{As per Fig 1 of IS 6403})$

$\phi' = 26, \text{ average } \phi = 31 \quad F.O.S = 2.5$

$N_q = 20.63, N_r = 30.22, S_q = 1.20, S_r = 0.80, W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 159.466 \text{ t/m}^2$$

$$Q_{safe} = 63.78 \text{ t/m}^2$$

Case IV

Df @ 193.50 B = 5.00m

$\phi = 36, (\text{As per Fig 1 of IS 6403})$

$\phi' = 26, \text{ average } \phi = 31 \quad F.O.S = 2.5$

$N_q = 20.63, N_r = 30.22, S_q = 1.20, S_r = 0.80, W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 171.546 \text{ t/m}^2$$

$$Q_{safe} = 68.61 \text{ t/m}^2$$

Settlement Criteria

Df (RL of Foundation depth in m)	Df @ RL 194.50		Df @ RL 193.50	
B (Width of foundation in m)	3.0m	5.0m	3.0m	5.0m
Settlement under footing with a load intensity of 10 t/m ² in dry condition	4.3mm	4.5mm	4.3mm	4.5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	9mm	9mm	9mm	9mm
Settlement under footing with a load intensity of 10 t/m ² with water table and depth correction	6mm	7mm	5.7mm	6.5mm
Net safe bearing pressure for allowable settlement of 25 mm (t/m ²)	41.66	35.71	43.88	38.46

Alternatively Raft Foundation

Shear Failure Criteria

Case I

Df @ 194.50

B >6.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_s s_s d_s i_s W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 154.04 t/m^2 \quad Q_{safe} = 61.61 t/m^2$$

Case II

Df @ 193.50

B >6.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_s s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 177.59 \text{ t/m}^2 \quad Q_{safe} = 71.03 \text{ t/m}^2$$

Settlement Criteria

Df (RL of Foundation depth in m)	Df@ RL 194.50	Df@ RL 193.50
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table, depth and rigidity correction	8mm	8mm
Net safe bearing pressure for allowable settlement of 40 mm (t/m ²)	50	50

BH 6 to BH 9 & BH 11 (Boiler)

Footing Foundation

Considering formation Level @ RL 199.500

Shear Failure Criteria

Case I

Df @ 194.50 B = 3.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_s s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 135.91 \text{ t/m}^2 \quad Q_{safe} = 54.36 \text{ t/m}^2$$

Case II

Df @ 194.50 B = 5.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 147.9 \text{ t/m}^2 \quad Q_{safe} = 59.20 \text{ t/m}^2$$

Case III

Df @ 193.50

B = 3.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 159.466 \text{ t/m}^2 \quad Q_{safe} = 63.78 \text{ t/m}^2$$

Case IV

Df @ 193.50

B = 5.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 171.546 \text{ t/m}^2 \quad Q_{safe} = 68.61 \text{ t/m}^2$$

Settlement Criteria

Df (RL of Foundation depth in m)	Df @ RL 194.50		Df @ RL 193.50	
B (Width of foundation in m)	3.0m	5.0m	3.0m	5.0m
Settlement under footing with a load intensity of 10 t/m ² in dry condition	4.3mm	4.5mm	4.3mm	4.5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	9mm	9mm	9mm	9mm
Settlement under footing with a load intensity of 10 t/m ² with water table and depth correction	6mm	7mm	5.7mm	6.5mm
Net safe bearing pressure for allowable settlement of 25 mm (t/m ²)	41.66	35.71	43.88	38.46

Alternatively Raft Foundation

Shear Failure Criteria

Case I

Df @ 194.50

B >6.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_s s_s d_s i_s W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 154.04 t/m^2 \quad Q_{safe} = 61.61 t/m^2$$

Case II

Df @ 193.50

B >6.00m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_y s_y d_y i_y W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 177.59 \text{ t/m}^2$$

$$Q_{safe} = 71.03 \text{ t/m}^2$$

Settlement Criteria

	Df@ RL 194.50	Df@ RL 193.50
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table, depth and rigidity correction	8mm	8mm
Net safe bearing pressure for allowable settlement of 40 mm (t/m ²)	50	50

Storage Tank (BH 10)

Considering formation Level @ RL 199.500

Df=197.50 Considering Dia of Tank 15.0m

Pad Foundation

Shear Failure Criteria

Average cohesion, $c = 7.50 \text{ t/m}^2$

$N_c = 5.14, s_c = 1.30; d_c = i_c = 1$


Using the equation

$$Q_{ult} = c N_c s_c d_c i_c N$$

Substituting the data in the equation given, we get

$$Q_{ult} = 7.50 \times 5.14 \times 1.3 = 50.115 \text{ t/m}^2$$

$$Q_{safe} = 20.04 \text{ t/m}^2$$



Settlement Criteria Considering 16.0t/m^2

Settlement at Center

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = 200/40 \times \log \{(3.0+16)/3.0\} = 40.07 \text{ mm}$$

$$S_{t2} = 250/190 \times \log \{(5.25+16)/5.25\} = 7.99 \text{ mm}$$

$$S_{t3} = 1000/250 \times \log \{(11.50+5.60)/11.50\} = 6.879 \text{ mm}$$

$$S_{t3} = S_{t1} + S_{t2} + S_{t3} = 54.95 \approx 55 \text{ mm}$$

Settlement at the edge

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = 200/40 \times \log \{(3.0+8)/3.0\} = 28.21 \text{ mm}$$

$$S_{t2} = 250/190 \times \log \{(5.25+7.20)/5.25\} = 4.934 \text{ mm}$$

$$S_{t3} = 1000/250 \times \log \{(11.50+3.20)/11.50\} = 4.26 \text{ mm}$$

$$S_{t3} = S_{t1} + S_{t2} + S_{t3} = 37.90 \approx 38 \text{ mm}$$

While Hydro testing the tank, tank shall be loaded in stages. At each stage of loading settlement shall be stabilised.

BH 12 & BH 14 (ESP)

Footing Foundation

Considering formation Level @ RL 199.500

Shear Failure Criteria

Case I

$$D_f @ 195.00 \quad B = 3.00 \text{m}$$

$$\phi = 35, (\text{As per Fig 1 of IS 6403})$$

$$\phi' = 25, \text{ average } \phi = 30 \quad F.O.S = 2.5$$

$$N_q = 18.40, N_r = 22.40, S_q = 1.20, S_r = 0.80, W' = 0.50$$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 96.96 t/m^2$$

$$Q_{safe} = 38.78 t/m^2$$

Case II

Df @ 195.00 B = 5.00m

$$\phi = 35, (\text{ As per Fig 1 of IS 6403})$$

$$\phi' = 25, \text{ average } \phi = 30 \quad F.O.S = 2.5$$

$$N_q = 18.40, N_r = 22.40, S_q = 1.20, S_r = 0.80, W' = 0.50$$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 110.40 t/m^2$$

$$Q_{safe} = 44.16 t/m^2$$

Case III

Df @ 193.50 B = 3.00m

$$\phi = 35, (\text{ As per Fig 1 of IS 6403})$$

$$\phi' = 25, \text{ average } \phi = 30 \quad F.O.S = 2.5$$

$$N_q = 18.40, N_r = 22.40, S_q = 1.20, S_r = 0.80, W' = 0.50$$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 117.84 t/m^2$$

$$Q_{safe} = 47.13 t/m^2$$

Case IV

Df @ 193.50 B = 5.00m

$$\phi = 35, (\text{ As per Fig 1 of IS 6403})$$

$$\phi' = 25, \text{ average } \phi = 30 \quad F.O.S = 2.5$$

$$N_q = 18.40, N_r = 22.40, S_q = 1.20, S_r = 0.80, W' = 0.50$$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_y s_y d_y i_y W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 126.80 t/m^2$$

$$Q_{safe} = 50.72 t/m^2$$

Settlement Criteria

Df (RL of Foundation depth in m)	Df@ RL 195		Df@ RL 193.50	
B (Width of foundation in m)	B=3.0	B=5.0	B=3.0	B=5.0
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm	5mm	5mm	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm	10mm	10mm	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table and depth correction	7mm	8mm	7mm	8mm
Net safe bearing pressure for allowable settlement of 25 mm (t/m ²)	35.71	31.25	35.71	31.25

BH 13 (ESP)

Footing Foundation

Considering formation Level @ RL 199.500

Shear Failure Criteria

Case I

Df @ 193.50 B = 3.00m

$\phi = 35$, (As per Fig 1 of IS 6403)

$\phi' = 25$, average $\phi = 30$ F.O.S = 2.5

$N_q = 18.40$, $N_r = 22.40$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q-1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 117.84 \text{ t/m}^2$$

$$Q_{safe} = 47.13 \text{ t/m}^2$$

Case II

Df @ 193.50 B = 5.00m

$\phi = 35$, (As per Fig 1 of IS 6403)

$\phi' = 25$, average $\phi = 30$ F.O.S = 2.5

$N_q = 18.40$, $N_r = 22.40$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q-1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 126.80 \text{ t/m}^2$$

$$Q_{safe} = 50.72 \text{ t/m}^2$$

Settlement Criteria

Df (RL of Foundation depth in m)	Df@ RL 193.50	
B (Width of foundation in m)	B=3.0	B=5.0
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table and depth correction	7mm	8mm
Net safe bearing pressure for allowable settlement of 25 mm (t/m ²)	35.71	31.25

Alternatively Raft Foundation

BH 12 & BH 14 (ESP)

Shear Failure Criteria

Case I

Df @ 195.00

B >6.00m

$\phi = 35$, (As per Fig 1 of IS 6403)

$\phi' = 25$, average $\phi = 30$ F.O.S = 2.5

$N_q = 18.40$, $N_r = 22.40$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_s s_s d_s i_s W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 110.40 \text{ t/m}^2 \quad Q_{safe} = 44.16 \text{ t/m}^2$$

Case II

Df @ 193.50

B >6.00m

$\phi = 35$, (As per Fig 1 of IS 6403)

$\phi' = 25$, average $\phi = 30$ F.O.S = 2.5

$N_q = 18.40$, $N_r = 22.40$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_y s_y d_y i_y W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 131.28 \text{ t/m}^2 \quad Q_{safe} = 52.51 \text{ t/m}^2$$

Settlement Criteria

Df = RL 195 to 193.50	
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table, depth and rigidity correction	8mm
Net safe bearing pressure for allowable settlement of 40 mm (t/m ²)	50

BH 13 (ESP)

Shear Failure Criteria

Case I

Df @ 193.50 B > 6.00m

$$\phi = 35, \text{ (As per Fig 1 of IS 6403)}$$

$$\phi' = 25, \text{ average } \phi = 30 \quad F.O.S = 2.5$$

$$N_q = 18.40, \quad N_r = 22.40, \quad S_q = 1.20, \quad S_r = 0.80, \quad W' = 0.50$$

Using the equation

$$Q_{ult} = q (N_q - 1) s_q d_q i_q + 0.5 B \gamma N_y s_y d_y i_y W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 131.28 \text{ t/m}^2 \quad Q_{safe} = 52.51 \text{ t/m}^2$$

Settlement Criteria

Df = RL 193.50	
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table, depth and rigidity correction	8mm
Net safe bearing pressure for allowable settlement of 40 mm (t/m ²)	50

BH 16 (Chimney)

Raft Foundation

Considering formation Level @ RL 199.500

Shear Failure Criteria

Case I

Df @ 190.00

B = 16.60m

$\phi = 36$, (As per Fig 1 of IS 6403)

$\phi' = 26$, average $\phi = 31$ F.O.S = 2.5

$N_q = 20.63$, $N_r = 30.22$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q - 1) S_q d_q i_q + 0.5 B \gamma N_r S_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 304.91 \text{ t/m}^2$$

$$Q_{safe} = 128.132 \text{ t/m}^2$$

Settlement Criteria

Df 190.00	B=16.60 m
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table, depth and rigidity correction	8mm
Net safe bearing pressure for allowable settlement of 40 mm (t/m ²)	50

BH 32 (Switch Yard)

Considering formation Level @ RL199.500

Footing Foundation

Case I

Df @ RL 196.00

Shear Failure Criteria

Average cohesion, $c = 4.50 \text{ t/m}^2$

$N_c = 5.14, s_c = 1.30; d_c = i_c = 1$

Using the equation

$$Q_{ult} = c N_c s_c d_c i_c N$$

Substituting the data in the equation given, we get

$$Q_{ult} = 4.50 \times 5.14 \times 1.3 = 30.069 \text{ t/m}^2$$

$$Q_{safe} = 12.02 \text{ t/m}^2$$

Settlement Criteria

Considering 12.0t/m² B= 2 to 4 m

$$e_0 = 0.82 \quad C_c = 0.063 \quad C_r = 150$$

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / (1 + e_0)\} \times C_c \times \log(P + \delta P / P)$$

$$S_{t2} = \{H / C_r\} \times \log(P + \delta P / P)$$

Using equation

Substituting the data we get.

$$S_{t1} = \{(100/1.82) \times 0.063 \log \{((3.5+12)/3.50)\}\} = 22.36\text{mm}$$

$$S_{t2} = \{(200/150) \times \log \{((4.5+5.4)/4.50)\}\} = 0.45\text{mm}$$

After depth correction < 25.0mm

Case II

Df @ 195.0 B = 2.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q-1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 64.30 \text{ t/m}^2 \quad Q_{safe} = 25.72 \text{ t/m}^2$$

Case III

Df @ 195.00 B = 3.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q-1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 67.65 \text{ t/m}^2 \quad Q_{safe} = 27.06 \text{ t/m}^2$$

Case IV

Df @ 195.00 B = 4.00m

$\phi = 34$, (As per Fig 1 of IS 6403)

$\phi' = 24$, average $\phi = 28$ F.O.S = 2.5

$N_q = 14.72$, $N_r = 16.72$, $S_q = 1.20$, $S_r = 0.80$, $W' = 0.50$

Using the equation

$$Q_{ult} = q (N_q-1) s_q d_q i_q + 0.5 B \gamma N_r s_r d_r i_r W'$$

Substituting the data in the equation given, we get

$$Q_{ult} = 70.976 \text{ t/m}^2 \quad Q_{safe} = 28.40 \text{ t/m}^2$$

Settlement Criteria

Df 195.00	B=2 to 4
Settlement under footing with a load intensity of 10 t/m ² in dry condition	5mm
Settlement under footing with a load intensity of 10 t/m ² with water table correction	10mm
Settlement under footing with a load intensity of 10 t/m ² with water table and depth correction	8mm
Net safe bearing pressure for allowable settlement of 25 mm (t/m ²)	31.00

BH 34 (Transformer Yard)

Considering formation Level @ RL199.500

Footing Foundation

Case I

Df @ RL 196.50

Shear Failure Criteria

Average cohesion, c = 20.0 t/m²

N_c = 5.14, s_c = 1.30; d_c = i_c = 1

Using the equation

$$Q_{ult} = c N_c s_c d_c i_c N$$

Substituting the data in the equation given, we get

$$Q_{ult} = 20.0 \times 5.14 \times 1.3 = 133.64 \text{ t/m}^2$$

$$Q_{safe} = 53.45 \text{ t/m}^2$$

Settlement Criteria

Case I

Considering 18.0t/m² B= 2 m

C_r=70

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = \{(300/70)\log \{((4.50+9)/4.50)\}\} = 20.45\text{mm}$$

After depth correction < 25.0mm

Case II

Considering 18.0t/m² B= 3 m

C_r=70

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = \{(450/70)\log \{((5.25+9)/5.25)\}\} = 27.88\text{mm}$$

After depth correction < 25.0mm

Case III

Considering 18.0t/m² B= 4 m

C_r=70

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = \{(600/70)\log \{((6.00+8.50)/6.00)\}\} = 32.85\text{mm}$$

After depth correction < 25.0mm

Case II

Df @ RL 195.50

Shear Failure Criteria

Average cohesion, c = 20.0 t/m²

N_c = 5.14, s_c = 1.30; d_c = i_c = 1

Using the equation

$$Q_{ult} = c N_c s_c d_c i_c N$$

Substituting the data in the equation given, we get

$$Q_{ult} = 20.0 \times 5.14 \times 1.3 = 133.64 \text{ t/m}^2$$

$Q_{safe} = 53.45 \text{ t/m}^2$

Settlement Criteria

Case I

Considering 20.0 t/m^2 $B = 2 \text{ m}$ $C_r = 70$

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = \{(300/70) \log \{((5.50+9)/5.50)\} = 18.04 \text{ mm}$$

After depth correction < 25.0mm

Case II

Considering 20.0 t/m^2 $B = 3 \text{ m}$ $C_r = 70$

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = \{(450/70) \log \{((6.25+9)/6.25)\} = 24.90 \text{ mm}$$

After depth correction < 25.0mm

Case III

Considering 20.0 t/m^2 $B = 4 \text{ m}$

$C_r = 70$

Settlement below the foundation can be obtained using the following equation,

$$S_{t1} = \{H / C_r \times \log (P + \delta P / P)\}$$

Using equation

Substituting the data we get.

$$S_{t1} = \{(600/70) \log \{((7.00+9.0)/7.00)\} = 30.76 \text{ mm}$$

After depth correction < 25.0mm

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

7.0 RECOMMENDATIONS

Transformer Yard

Footing Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Safe Bearing pressure (t/m ²)
BH 1, BH 2 & BH 34	196.50	2	15
		3	17
		4	18
	195.50	2	20
		3	20
		4	20

Power House Block

Footing Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Safe Bearing pressure (t/m ²)
BH 3 to BH 5	194.500	3.00	40
		5.00	35
	193.500	3.00	40
		5.00	38

Alternatively, Raft Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Safe Bearing pressure (t/m ²)
BH 3 to BH 5	194.500	>6	50
	193.500	50	

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

Boiler

Footing Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Net Safe Bearing pressure (t/m²)
BH 6 to 9 & BH 11	194.500	3.00	40
		5.00	35
	193.500	3.00	40
		5.00	38

Alternatively, Raft Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Net Safe Bearing pressure (t/m²)
BH 6 to 9 & BH 11	194.500	>6	50
	193.500	>6	50

ESP

Footing Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Net Safe Bearing pressure (t/m²)
BH 12 & BH 14	195.00 to 193.50	3	30
		5	31
BH 13	193.50	3	30
		5	31

Alternatively, Raft Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Net Safe Bearing pressure (t/m²)
BH 12 & BH 14	193.50 to 195	>6	50
BH 13	193.50	>6	50

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I

Switch Yard

Footing Foundation is recommended. The depth of foundation, width of foundation and the safe bearing pressure are as given below:

BH	Df @ RL	Width of Fdn (m)	Net Safe Bearing pressure (t/m²)
32	196	2 to 4	12
	195	2	25
		3	27
		4	28

Storage Tank (BH 10)

Pad foundation is recommended @ RL 197.50. A Net safe bearing pressure of 16 t/m² can be taken for the design of 10.0m dia pad Foundation. While hydro testing the tanks, loading can be done at eight stages. At each stage of load increment, the settlements shall be stabilised.

Chimney (BH 16)

Raft Foundation is recommended at RL 190.00. A net Safe bearing pressure of 50 t/m² can be taken for the design of Raft foundation for an allowable settlement of 40mm.

For all Structures

In case of any change in width of foundation and depth of foundation other than given above, recommendation for the changed sizes shall be provided as and when required.

For Soil Engineering Consultants

(AVS Ranga Rao)
Consultant

Annexure I

ROCK TEST RESULT

S.No	Area	BH	Depth (m)		Density (t/m ³)
			From	To	
1	Transformer Yard	1	7.50	9.00	2.09
2			9.00	10.50	2.02
3			10.50	12.00	2.14
4			12.00	13.50	2.07
5			13.50	15.00	2.09
6		2	5.00	6.00	2.15
7			6.00	7.50	2.14
8			7.50	9.00	2.07
9			9.00	10.50	2.26
10			10.50	12.00	2.24
11			12.00	13.50	2.23
12			13.50	15.00	2.12
13	Power Block	3	6.00	7.50	2.14
14			7.50	9.00	2.04
15			9.00	10.50	2.14
16			10.50	12.00	2.40
17			12.00	13.50	2.11
18			13.50	15.00	2.08
19			19.50	21.00	2.09
20			21.00	22.50	2.15
21			22.50	24.00	2.18
22			24.00	25.00	2.22
23	4	21.00	22.50	2.23	
24		22.50	24.00	2.22	
25		24.00	25.00	2.37	
26	5	8.00	9.00	2.00	
27		9.00	10.50	2.17	
28	Boiler	6	8.00	9.50	2.13
29			9.50	10.50	2.15
30			10.50	12.00	2.15
31			21.00	22.50	2.21
32			22.50	24.00	2.23
33			24.00	25.00	2.32

**Project: 2x660MW IB TPS UNIT-3 & 4, OPGCL, BANHARPALLI,
DIST. – JHARSUGUDA, ODISHA**

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I



S.No	Area	BH	Depth (m)		Density(t/m³)
			From	To	
34	Boiler	7	4.50	6.00	2.23
35			6.00	7.50	2.27
36			7.50	9.00	2.12
37			9.00	10.50	2.28
38			10.50	12.00	2.25
39			12.00	13.50	2.23
40			18.00	19.50	2.16
41			19.50	21.00	2.29
42			21.00	22.50	2.14
43			22.50	24.00	2.12
44			24.00	25.00	2.25
45	Boiler	8	4.50	6.00	2.09
46			6.00	7.50	2.00
47			9.00	10.00	2.15
48			13.50	15.00	2.08
49			15.00	16.50	2.08
50			16.50	18.00	2.26
51			18.00	19.50	2.20
52			19.50	21.00	2.12
53			21.00	22.50	2.42
54			22.50	24.00	2.44
55			24.00	25.00	2.11
56	Boiler	9	18.00	19.50	2.18
57			19.50	21.00	2.20
58			21.00	22.50	2.14
59			22.50	24.00	2.19
60			24.00	25.00	2.12
61	Boiler	11	3.50	4.50	2.19
62			4.50	6.00	2.17
63			6.00	7.50	2.04
64			7.50	9.00	2.00
65			9.00	10.50	2.23
66			10.50	12.00	2.04
67			12.00	13.50	2.12
68			13.50	15.00	2.07
69			15.00	16.50	2.22
70			19.50	19.50	2.00
71			21.00	21.00	2.17
72			22.50	22.50	2.18
73			24.00	25.00	2.17

**Project: 2x660MW IB TPS UNIT-3 & 4, OPGCL, BANHARPALLI,
DIST. – JHARSUGUDA, ODISHA**

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I



S.No	Area	BH	Depth(m)		Density(t/m ³)
			From	To	
74	Switch Yard	32	6.00	7.50	2.15
75			7.50	9.00	2.15
76			9.00	10.50	2.22
77			10.50	12.00	2.19
78			12.00	13.50	2.25
79			13.50	15.00	2.31

**Project: 2x660MW IB TPS UNIT-3 & 4, OPGCL, BANHARPALLI,
DIST. – JHARSUGUDA, ODISHA**

GEOTECHNICAL INVESTIGATION REPORT - VOLUME-I




Annexure II

FREE SWELL INDEX

S.No	BH No	Depth	Free Swell Index (%)
1	1	1.8	0
2		3.3	0
3	2	1.8	0
4		3.3	0
5	3	3	0
6	7	1.8	0
7		3.3	0
8	8	3.3	0
9	9	3.3	0
10		4.8	0
11	11	1.8	0
12	32	1.8	0
13		3.3	0



BOREHOLE LOCATION PLAN





BORE LOGS

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1394 E, 1316 S RL: 203.000 Project No: 1988

Location: Transformer Yard BH No. : 1 DEPTH : 15.00m Depth of Water Table : 2.60m Date of Start : 28/09/2013 Date of Finish : 30/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)		Density (gm/cc)		W/C	Limits (%)	Sp.Gr	Shear Parameters			Cc
				Observed		Gravel	Sand	Silt/Clay	r(wet)				W(%)	L.L	P.L	
203.000	0.00	SPT	Filledup Soil (Soil Mixed with Building Material)	0	20	40	60	80	100	120						
201.200	1.80		Silty Clay of medium to High Plasticity (CH)	1.00	*	14										
200.500	2.50			2.00	*	26										
199.700	3.30			3.00												
198.500	4.50		Refusal Strata	4.00												
				5.00	15cm, 66 Blows		12	57	31							
				6.00												
				7.00												
				8.00												
				9.00												
				10.00												
				11.00												
				12.00												



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1394 E, 1316 S RL: 203.000 Project No: 1988

Location: Transformer Yard BH No.: 1 DEPTH : 15.00m Depth of Water Table : 2.60m Date of Start : 28/09/2013 Date of Finish : 30/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG									TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL TIME INTERVAL	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD
198.500	4.50	Highly weathered highly fractured yellowish color Sandstone/Siltstone			0 20 40 60 80 100	0 20 40 60 80	0 20 40 60 80 100			0 20 40 60 80 100							CR(CM)=22 CR(%)=15 RQD(%)=Nil N>100
197.000	6.00	Highly weathered disintegrated Rock			0 20 40 60 80 100	0 20 40 60 80	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=Nil, CR(%)=Nil RQD(%)=Nil N>100 Penetration 10 cm 68 Blows
195.500	7.50				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=76 CR(%)=51 RQD(%)=37
194.000	9.00	Highly weathered and fractured greyish color Shale			0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=128 CR(%)=85 RQD(%)=67
192.500	10.50				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100							CR(CM)=101 CR(%)=67 RQD(%)=34
191.000	12.00	Highly weathered highly fractured greyish color Shale			0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=60 CR(%)=40 RQD(%)=Nil
189.500	13.50	Highly weathered and fractured greyish color Shale			0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100							CR(CM)=102 CR(%)=67 RQD(%)=41
188.000	15.00				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100							

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1495 E, 1316 S

RL: 201.800

Project No: 1988

Location: Transformer Yard BH No. :2 DEPTH : 15.00m Depth of Water Table : 2.80m Date of Start : 01/10/2013 Date of Finish : 03/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot			Grain size (%)		Density (gm/cc)		W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc		
				Observed			Gravel	Sand	Silt/Clay	r(wet)	r(dry)			Sp.Gr	Type of test	C(kg/sqcm)		
201.800	0.00		Filledup Soil (Soil Mixed with Leaves etc)	0 20 40 60 80 100 120	0.00													
200.000	1.80	SPT			1.00													
199.300	2.50	UDS	Silty Clay of medium to High Plasticity (CI-CH)		2.00		17	19	43/21	1.86	1.52	22.18	46	28	2.78	UU	0.94	0.059
198.500	3.30	SPT			3.00		2	16	67/15				54	31				
197.000	4.80	SPT			4.00													
196.800	5.00	SPT	Refusal Strata		5.00		1	15	70/14 41									
					6.00													
					7.00													
					8.00													
					9.00													
					10.00													
					11.00													
					12.00													

15 cm, 69 Blows



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1495 E, 1316 S RL: 201.800

Project No: 1988

Location: Transformer Yard

BH No.: 2

DEPTH : 15.00m

Depth of Water Table : 2.80m

Date of Start : 01/10/2013

Date of Finish : 03/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING mm NX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS
		DESCRIPTION	LOG										TEST SECTION	PRESSURE (kg/sq.cm)	LOSS (ml)	DEPTH OF WATER LEVEL	TIME INTERVAL
196.800	5.00																CR(CM)=39 CR(%)=39 RQD(%)=39
195.800	6.00																CR(CM)=88 CR(%)=59 RQD(%)=21
194.300	7.50	Highly weathered and fractured yellowish color Sandstone/ Siltstone															CR(CM)=101 CR(%)=67 RQD(%)=40
192.800	9.00																CR(CM)=86 CR(%)=57 RQD(%)=35
191.300	10.50																CR(CM)=52 CR(%)=35 RQD(%)=8
189.800	12.00	Highly weathered and fractured greyish color Shale															CR(CM)=108 CR(%)=72 RQD(%)=59
188.300	13.50																CR(CM)=85 CR(%)=57 RQD(%)=Nil
186.800	15.00	Highly weathered highly fractured greyish color Shale															



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1450 E, 1369 S RL: 202.800 Project No : 1988

Location: Power House Block BH No. : 3 DEPTH : 25.00m Depth of Water Table :2.40 m Date of Start : 01/09/2013 Date of Finish : 20/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)		Density (gm/cc)	W/C	Limits (%)		Shear Parameters	Cc	
				Observed		Gravel	Sand			W(%)	L.L	P.L		
				0	20	40	60	80	100	120			Sp.Gr	Type of test
202.800	0.00	SPT	Filledup Soil (Soil)											
201.000	1.80		Sandy Silt with Gravel (SM-ML)											
200.300	2.50		UDS											
199.800	3.00		SPT	Silty Clay of medium Plasticity (CL)										
198.300	4.50			Refusal Strata										

*25

*15

10 cm, 77 Blows

*100



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.										Coordinate: 1450 E, 1369 S RL: 202.800			Project No : 1988																
Location: Power House Block BH No. : 3 DEPTH : 25.00m Depth of Water Table :2.40 m		Date of Start : 01/09/2013 Date of Finish : 20/09/2013																											
REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS NO PARTIAL COMPLETE	PERCOLATION TEST			PERMEABILITY	REMARKS									
		DESCRIPTION																											
198.300	4.50	Highly weathered highly fractured yellowish color Sandstone/ Siltstone		Highly weathered and fractured yellowish color Sandstone/ Siltstone																									
196.800	6.00																												
195.300	7.50																												
193.800	9.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone																											
192.300	10.50																												
190.800	12.00																												
189.300	13.50																												
187.800	15.00																												



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1450 E, 1369 S RL: 202.800

Project No : 1988

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS NO PARTIAL COMPLETE	PERCOLATION TEST			PERMEABILITY	REMARKS				
		Size of core pieces											BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD							
		< 10 mm size	10 to 25 mm	25 to 75 mm	75 to 150 mm	> 150 mm							PRESSURE (kg/sq cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL					
187.800	15.00	Highly weathered disintegrated Rock						NX									CR(CM)=Nil, CR(%)=Nil RQD(%)=Nil N>100 Penetration 5 cm 70 Blows				
186.300	16.50																				
184.800	18.00																				
183.300	19.50																				
181.800	21.00																				
180.300	22.50																				
178.800	24.00																				
177.800	25.00																				

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1315 E, 1369 S RL: 201.128 Project No : 1988

Location: Power House Block BH No. : 4 DEPTH : 25.00m Depth of Water Table : 0.40m Date of Start : 21/09/2013 Date of Finish : 24/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot			Grain size (%)		Density (gm/cc)	W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc			
				Observed			Gravel	Sand					r(wet)	r(dry)	W(%)	L.L	P.I	
201.128	0.00	SPT	Filledup Soil(Soil)															
199.328	1.80		Sandy Silt with Gravel (SM-ML)															
198.628	2.50		UDS															
198.128	3.00		SPT															
196.628	4.50		Silty Sand with Gravel (SM)															
195.128	6.00		SPT															
			Sandy Silt with Gravel (SM-ML)															
			Refusal Strata															

BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1315 E, 1369 S RL: 201.128

Project No : 1988

Location: Power House Block BH No. : 4 DEPTH : 25.00m Depth of Water Table : 0.40m

Date of Start : 21/09/2013 Date of Finish : 24/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		LOG	Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS NO PARTIAL COMPLETE	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG												TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(l/m)	DEPTH OF WATER LEVEL	TIME INTERVAL	
195.128	6.00	Highly weathered Highly fractured yellowish color Sandstone/ Siltstone						0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100					CR(CM)=5 CR(%)=3 RQD(%)=Nil N>100 Penetration 11 cm 77 Blows	
193.628	7.50																			CR(CM)=Nil,CR(%)=Nil RQD(%)=Nil N>100 Penetration 8cm 68 Blows
192.128	9.00	Highly weathered disintegrated Rock											NX							CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 9cm 70 Blows
190.628	10.50												NX							CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 6cm 65 Blows
189.128	12.00	Highly weathered Highly fractured yellowish color Sandstone/siltstone											NX							CR(CM)=5 CR(%)=3 RQD(%)=Nil N>100 Penetration 5Cm 63 Blows
187.628	13.50	Highly weathered disintegrated Rock											NX							CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 6cm 71 Blows
186.128	15.00																			



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1315 E, 1369 S

RL: 201.128

Project No : 1988

Location: Power House Block BH No. : 4 DEPTH : 25.00m Depth of Water Table : 0.40m Date of Start : 21/09/2013 Date of Finish : 24/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	LOG	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS
		DESCRIPTION	LOG												BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD			
186.128	15.00			<10 mm size	10 to 25 mm	25 to 75 mm	75 to 150 mm	>150 mm											
184.628	16.50																		
183.128	18.00	Highly weathered disintegrated Rock																	
181.628	19.50																		
180.128	21.00																		
178.628	22.50	Moderately weathered and fractured yellowish to greyish color Sandstone/ Siltstone																	
177.128	24.00																		
176.128	25.00																		

BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1237 E, 1369 S RL: 199.744 Project No : 1988

Location: Power House Block BH No. : 5 DEPTH : 25.00m Depth of Water Table : 0.40m Date of Start : 01/09/2013 Date of Finish : 20/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)		Density (gm/cc)		W/C	Limits (%)	Sp.Gr	Shear Parameters			Cc	
				Observed									r(wet)	r(dry)	W(%)	L.L	P.L
199.744	0.00		Filledup Soil (Soil)	0.00													
197.944	1.80	SPT		1.00													
196.744	3.00	SPT		2.00	*	91		1	50	49						Non Plastic	
195.244	4.50	SPT	Silty Sand with Gravel (SM)	3.00	15cm, 79 Blows	*	100	2	64	34						Non Plastic	
193.744	6.00	SPT		4.00	10cm, 86 Blows	*	100	1	64	35						Non Plastic	
192.244	7.50	SPT		5.00	15cm, 91 Blows	*	100	1	65	34						Non Plastic	
191.744	8.00	SPT		6.00	12cm, 88 Blows	*	100	1	74	25						Non Plastic	
			Refusal Strata	7.00	15cm, 96 Blows	*	100	12	64	24						Non Plastic	
				8.00													
				9.00													
				10.00													
				11.00													
				12.00													



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1237 E, 1369 S RL: 199.744

Project No : 1988

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	GROUT	OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS
		DESCRIPTION	LOG													BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD			
191.744	8.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone																		
190.744	9.00																			
189.244	10.50																			
187.744	12.00																			
186.244	13.50																			
184.744	15.00																			
183.244	16.50																			

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1237 E, 1369 S RL: 199.744 Project No : 1988

Location: Power House Block BH No. : 5 DEPTH : 25.00m Depth of Water Table : 0.40m Date of Start : 01/09/2013 Date of Finish : 20/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING	OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS									
		DESCRIPTION	LOG												0	20	40	60	80	100	NO	PARTIAL	COMPLETE	TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD		
183.244	16.50						0	20	40	60	80	100			0	20	40	60	80	100								
181.744	18.00	Highly weathered disintegrated Rock																										
180.244	19.50	Highly weathered and fractured yellowish color Sandstone/ Siltstone																										
178.744	21.00																											
177.244	22.50	Highly weathered disintegrated Rock																										
175.744	24.00																											
174.744	25.00																											

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha

Coordinates: 1275 E, 1422 S RL: 200.125

Project No: 1988

Location: Boiler BH No. : 6 DEPTH : 25.00m Depth of Water Table : 0.50m

Date of Start : 31/08/2013 Date of Finish : 18/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)		Density (gm/cc)	W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc
				Observed		Gravel	Sand					Type of test	C(kg/sq.cm)	
200.125	0.00	SPT	Filledup Soil (Soil)											
198.325	1.80		Sandy Silt with Gravel (SM-ML)	*56		3	36	61					Non Plastic	
196.825	3.30			*78		5	21	74					Non Plastic	
195.375	4.75		Silty Sand with Gravel (SM)	15 cm, 80 Blows *100		3	13	84					Non Plastic	
194.025	6.10			10 cm, 80 Blows *100		1	64	35					Non Plastic	
192.535	7.59		Refusal Strata	9 cm, 92 Blows *100		1	63	36					Non Plastic	
191.625	8.50			10 cm, 85 Blows *100		18	70	12					Non Plastic	



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha

RL: 200.125

Project No: 1988

Location: Boiler BH No. : 6 DEPTH : 25.00m Depth of Water Table : 0.50m

Date of Start : 31/08/2013 Date of Finish : 18/09/2013

REDUCED LEVEL (m)	DEPTH	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	Casing OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG											TEST SECTION	PRESSURE (kg/sq cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL	
191.625	8.50																		CR(CM)=17,CR(%)=34 RQD(%)=Nil
191.125	9.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone																	CR(CM)=68 CR(%)=45 RQD(%)=23 N>100
189.625	10.50																		CR(CM)=35 CR(%)=23 RQD(%)=23 N>100
188.125	12.00																		CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 9cm Blows 78
186.625	13.50																		CR(%)=Nil RQD(%)=Nil N>100 Penetration 7cm Blows 69
185.125	15.00	Highly weathered disintegrated Rock																	CR(%)=Nil RQD(%)=Nil N>100 Penetration 69cm Blows 57
183.625	16.50																		

SOIL ENGINEERING CONSULTANTS



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha

Coordinates: 1275 E, 1422 S RL: 200.125

Projrct No: 1988

Location: Boiler BH No. : 6 DEPTH : 25.00m Depth of Water Table : 0.50m

Date of Start : 31/08/2013 Date of Finish : 18/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	< 10 mm size	10 to 25 mm	25 to 75 mm	75 to 150 mm	> 150 mm	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES	mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS																	
		DESCRIPTION	LOG																	TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL																		
183.625	16.50																																									
182.125	18.00	Highly weathered disintegrated Rock																								CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100																
180.625	19.50																																									
179.125	21.00																									CR(CM)=69 CR(%)=46 RQD(%)=18 N>100																
177.625	22.50	Highly weathered and fractured yellowish color Sandstone																								CR(CM)=67 CR(%)=45 RQD(%)=10 N>100																
176.125	24.00	Highly weathered Highly fractured Greyish color Shale																								CR(CM)=42 CR(%)=42 RQD(%)=Nil N>100																
175.125	25.00	Highly weathered Highly fractured Greyish color Shale																																								



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha

Coordinate: 1275 E, 1422 S RL: 202.100

Project No: 1988

Location: Boiler BH No.: 7 DEPTH : 25.00m Depth of Water Table : 2.45 m

Date of Start : 26/09/2013 Date of Finish : 30/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)		Density (gm/cc)		W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc	
				Observed				r(wet)	r(dry)				Type of test	C(kg/sqcm)	phi(degrees)	
202.100	0.00	SPT	Filledup Soil(Soil)	0	20	40	60	80	100	120	0.00	1.00	2.00	3.00	4.00	15cm, 77 Blows *100
200.300	1.80		Silty Clay mixed with Sand (CI)	1	20	56/23	1.89	1.51	25.13	39	20	2.76	UU	1.46	3	0.058
199.600	2.50			1	35	44/20										
198.800	3.30		Refusal Strata	1	22	61/16										
197.600	4.50															



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1275 E, 1422 S RL: 202.100

Project No: 1988

Location: Boiler BH No. : 7 DEPTH : 25.00m Depth of Water Table : 2.45 m

Date of Start : 26/09/2013 Date of Finish : 30/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS
		DESCRIPTION	LOG										PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL	
197.600	4.50						0 20 40 60 80 100	0 20 40 60 80 100	mm NX BX AX		0 20 40 60 80 100						CR(CM)=31 CR(%)=21 RQD(%)=9 N>100
196.100	6.00																CR(CM)=27 CR(%)=18 RQD(%)=Nil N>100
194.600	7.50	Highly weathered Highly fractured yellowish color Sandstone/ Siltstone							NX								CR(CM)=33 CR(%)=22 RQD(%)=Nil N>100
193.100	9.00								NX								CR(CM)=17 CR(%)=11 RQD(%)=Nil N>100 Penetration 6cm Blows 59
191.600	10.50																CR(CM)=13 CR(%)=9 RQD(%)=Nil N>100 Penetration 5cm 55 Blows
190.100	12.00								NX								CR(CM)=12 CR(%)=8 RQD(%)=Nil N>100 Penetration 9cm 72 Blows
188.600	13.50																CR(CM)=12 CR(%)=8 RQD(%)=Nil N>100
187.100	15.00																



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha

Coordinate: 1275 E, 1422 S RL: 202.100

Project No: 1988

Location: Boiler BH No. : 7 DEPTH : 25.00m Depth of Water Table : 2.45 m

Date of Start : 26/09/2013 Date of Finish : 30/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING mm NX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS								
		DESCRIPTION	LOG										TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD										
		DEPTH (m)	LOG	DESCRIPTION		0	20	40	60	80	100		0	20	40	60	80	100	0	20	40	60	80	100	
187.100	15.00																								
185.600	16.50	Highly weathered disintegrated Rock	Nil																						
184.100	18.00																								
182.600	19.50	Highly weathered and fractured yellowish color Sandstone/ Siltstone																							
181.100	21.00																								
179.600	22.50																								
178.100	24.00	Highly weathered and fractured Greyish color Shale																							
177.100	25.00																								

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha

Coordinate: 1453 E, 1447 S RL: 202.440 Project No: 1988

Location: Boiler BH No.: 8 DEPTH : 25.00m Depth of Water Table : 2.80 m

Date of Start : 26/09/2013 Date of Finish : 29/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot			Grain size (%)		Density (gm/cc)	W/C	Limits (%)		Sp.Gr	Shear Parameters		Cc					
				Observed						Gravel	Sand	Silt/Clay	r(wet)	r(dry)	W(%)	L.L	P.I.	Type of test	C(kg/sq.cm)	phi(degrees)	
				0	20	40	60	80	100												
202.440	0.00	SPT	Filledup Soil (Soil mixed with Road Material)	0.00																	
200.640	1.80		Silty Clay mixed with Sand (CL)	1.00	*	17				0	24	54/22									
199.940	2.50		UDS	2.00														2.76			
199.140	3.30			3.00	*	65				0	39	40/20	1.85	1.50	23.64	42	25	UU	0.94	3	0.061
198.940	3.50		SPT	4.00						1	35	65									
				5.00																	
			Refusal Strata		6.00																
					7.00																
					8.00																
					9.00																
					10.00																
					11.00																
					12.00																



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banarpalli, Dist-Jharsugura, Odisha

Coordinate: 1453 E, 1447 S RL: 202.440

Project No: 1988

Location: Boiler BH No. : 8 DEPTH : 25.00m Depth of Water Table : 2.80 m

Date of Start : 26/09/2013 Date of Finish : 29/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mm NX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG										TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD			
198.940	3.50					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100						
197.940	4.50	Highly weathered Highly fractured yellowish color Sandstone/ Siltstone				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100					CR(CM)=35 CR(%)=35 RQD(%)=Nil	
196.440	6.00									NX								CR(CM)=61 CR(%)=41 RQD(%)=7
194.940	7.50	Highly weathered disintegrated Rock				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=54 CR(%)=36 RQD(%)=Nil
193.440	9.00	Highly weathered Highly fractured yellowish color Sandstone				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 5cm 50 Blows
191.940	10.50					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=15 CR(%)=10 RQD(%)=Nil
190.440	12.00	Highly weathered disintegrated Rock				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 4cm 61 Blows
188.940	13.50									NX								CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 5cm 65 Blows



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha

Coordinate : 1468 E, 1447 S RL: 202.440

Job No: 1988

Location: Boiler BH No. : 8 DEPTH : 25.00m Depth of Water Table : 2.80 m

Date of Start : 26/09/2013 Date of Finish : 29/09/2013

REDUCED LEVEL	DEPTH	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mm NX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG													TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL	
188.940	13.50	Highly weathered and fractured yellowish color Sandstone									NX									CR(CM)=33 CR(%)=22 RQD(%)=10	
187.440	15.00																				CR(CM)=60 CR(%)=40 RQD(%)=34
185.940	16.50																				CR(CM)=73 CR(%)=49 RQD(%)=43
184.440	18.00																				CR(CM)=101 CR(%)=67 RQD(%)=47
182.940	19.50																				CR(CM)=125 CR(%)=33 RQD(%)=61
181.440	21.00																				CR(CM)=111 CR(%)=74 RQD(%)=29
179.940	22.50																				CR(CM)=94 CR(%)=62 RQD(%)=28
178.440	24.00																				CR(CM)=58 CR(%)=58 RQD(%)=53
177.440	25.00																				



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha

Coordinate: 1480 E, 1497 S RL: 201.900

Project No: 1988

Location: Boiler BH No. : 9 DEPTH : 25.00m Depth of Water Table : 2.65m

Date of Start : 03/10/2013 Date of Finish : 04/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot			Grain size (%)			Density (gm/cc)	W/C	Limits (%)	Sp.Gr	Shear Parameters			Cc	
				Observed			Gravel	Sand	Silt/Clay					r(wet)	r(dry)	W(%)	L.I.	P.L
201.900	0.00	SPT	Filledup Soil(Soil)	0.00														
200.100	1.80		Sandy Silt with Gravel (SM-ML)	1.00														
199.400	2.50			2.00														
198.600	3.30			3.00														
197.100	4.80		Silty Clay of medium Plasticity (CL)	4.00														
195.900	6.00		Refusal Strata	5.00														
				6.00														
				7.00														
				8.00														
				9.00														
				10.00														
				11.00														
				12.00														

*31

*25

*44

5 cm, 65 Blows

*100

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha

Coordinate: 1480 E, 1497 S RL: 201.900

Project No: 1988

Location: Boiler BH No. : 9 DEPTH : 25.00m Depth of Water Table : 2.65m

Date of Start : 03/10/2013 Date of Finish : 04/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mm NX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS							
		DESCRIPTION	LOG											0	20	40	60	80	100	TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD			
195.900	6.00																								
194.400	7.50	Highly weathered disintegrated Rock																							
192.900	9.00																								
191.400	10.50																								
189.900	12.00																								
188.400	13.50	Highly weathered Highly fractured yellowish color Sandstone/ Siltstone																							
186.900	15.00																								



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha

Coordinate: 1480 E, 1497 S

RL: 201.900

Project No: 1988

Location: Boiler BH No. : 9 DEPTH : 25.00m Depth of Water Table : 2.65m

Date of Start : 03/10/2013 Date of Finish : 04/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS
		DESCRIPTION	LOG													TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL
186.900	15.00								0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100					CR(CM)=20 CR(%)=13 RQD(%)=Nil N>100 Penetration 7 cm 72 Blows
185.400	16.50	Highly weathered Highly fractured yellowish color Sandstone/ Siltstone																		CR(CM)=18 CR(%)=12 RQD(%)=Nil N>100 Penetration 4 cm 60 Blows
183.900	18.00																			CR(CM)=36 CR(%)=24 RQD(%)=Nil
182.400	19.50																			CR(CM)=51 CR(%)=34 RQD(%)=27
180.900	21.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone																		CR(CM)=63 CR(%)=42 RQD(%)=12
179.400	22.50																			CR(CM)=44 CR(%)=29 RQD(%)=16
177.900	24.00	Highly weathered and fractured greyish color Shale																		CR(CM)=72 CR(%)=72 RQD(%)=55
176.900	25.00																			

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1385 E, 1497 S

RL: 200.200

Project No: 1988

Location: Storage Tank & P/H BH No.: 10 DEPTH : 25.00m Depth of Water Table 0.90m Date of Start : 08/10/2013 Date of Finish : 10/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)			Density (gm/cc)		W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc							
				Observed																			
				0	20	40	60	80	100	120													
200.000	0.00	SPT	Filledup Soil (Soil, Low Lying Area)																				
198.400	1.80		Silty Clay mixed with Sand (CL)																				
197.700	2.50																						
196.900	3.30		Silty Sand with Gravel (SM)																				
195.700	4.50																						
194.200	6.00		Refusal Strata																				
193.700	6.50																						

12.00

B10-1/3



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1385 E, 1497 S RL: 200.200

Project No: 1988

Location: Storage Tank & P/H

BH No. : 10

DEPTH : 25.00m

Depth of Water Table 0.90m

Date of Start : 08/10/2013

Date of Finish : 10/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS NO 20 PARTIAL 40 60 80 COMPLETE 100	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG											TEST SECTION	PRESSURE (kg/sq.cm)	LOSS (ml)	DEPTH OF WATER LEVEL	TIME INTERVAL	
193.700	6.50						0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100				0 NO 20 PARTIAL 40 60 80 COMPLETE 100						
192.700	7.50	Highly weathered disintegrated Rock																	CR(CM)=Nil, CR(%)=Nil RQD(%)=Nil N>100 12cm, 75 Blows
191.200	9.00																		CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 7 cm, 70 Blows
189.700	10.50																		CR(CM)=18 CR(%)=12 RQD(%)=Nil N>100 8cm, 68 Blows
188.200	12.00	Highly weathered highly fractured yellowish color Sandstone																	CR(CM)=21 CR(%)=14 RQD(%)=Nil N>100 6cm, 59 Blows
186.700	13.50																		CR(CM)=15 CR(%)=10 RQD(%)=Nil N>100 5cm, 66 Blows
185.200	15.00	Highly weathered disintegrated Rock																	CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 4 cm, 62 Blows
183.700	16.50	Highly weathered and fractured yellowish color Sandstone																	CR(CM)=43 CR(%)=29 RQD(%)=23



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1385 E, 1497 S RL:200.200

Project No: 1988

Location: Storage Tank & P/H BH No. : 10 DEPTH : 25.00m Depth of Water Table 0.90m

Date of Start : 08/10/2013 Date of Finish : 10/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS		
		DESCRIPTION	LOG								GROUT	OTHER SIZES	DEPTH OF WATER LEVEL	NO	PARTIAL	COMPLETE	
183.700	16.50	Highly weathered highly fractured yellowish color Sandstone/ Siltstone				0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=29 CR(%)=19 RQD(%)=Nil
182.200	18.00	Highly weathered disintegrated Rock				1 30 50 70 90	1 30 50 70 90	NX		1 30 50 70 90							CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 5cm, 65 Blows
180.700	19.50					2 40 60 80 100	2 40 60 80 100	NX		2 40 60 80 100							CR(CM)=24 CR(%)=16 RQD(%)=Nil
179.200	21.00					3 50 70 90	3 50 70 90	NX		3 50 70 90							CR(CM)=20 CR(%)=13 RQD(%)=Nil N>100 4cm, 59 Blows
177.700	22.50	Highly weathered highly fractured yellowish color Sandstone/ Siltstone				4 60 80 100	4 60 80 100	NX		4 60 80 100							CR(CM)=19 CR(%)=13 RQD(%)=Nil N>100 5 cm, 62 Blows
176.200	24.00					5 70 90	5 70 90			5 70 90							CR(CM)=21 CR(%)=21 RQD(%)=Nil
175.200	25.00																



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1275 E, 1497 S RL: 199.631 Project No: 1988

Location: Boiler BH No. : 11 DEPTH : 25.00m Depth of Water Table : 1.10 m

Date of Start : 03/09/2013 Date of Finish : 21/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot			Grain size (%)		Density (gm/cc)		W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc					
				Observed			Gravel	Sand	Silt/Clay	r(wet)	r(dry)			L.L	P.L	Type of test	C(kg/sq.cm)	phi(degrees)			
199.631	0.00		Filledup Soil(Soil)	0	20	40	60	80	100	120											
197.831	1.80	SPT	Silty Clay of medium Plasticity (CI)	1.00	*	11															
197.131	2.50	UDS		2.00			2	38	52/8												
196.331 196.131	3.30 3.50	SPT SPT	Refusal Strata	3.00	*	28		1	66	30/0	1.82	1.46	24.78		39	20	2.78	UU	0.82	3	0.061
				4.00																	
				5.00																	
				6.00																	
				7.00																	
				8.00																	
				9.00																	
				10.00																	
				11.00																	
				12.00																	



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1275 E, 1497 S RL: 199.631

Project No: 1988

Location: Boiler BH No. : 11 DEPTH : 25.00m Depth of Water Table : 1.10 m

Date of Start : 03/09/2013 Date of Finish : 21/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	Casing OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST		PERMEABILITY	REMARKS	
		DESCRIPTION	LOG												TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD		
196.131	3.50	Highly weathered Highly fractured yellowish color Sandstone/ Siltstone																	CR(CM)=47 CR(%)=47 RQD(%)=Nil
195.131	4.50																		CR(CM)=60 CR(%)=40 RQD(%)=Nil
193.631	6.00											NX							CR(CM)=89 CR(%)=59 RQD(%)=13
192.131	7.50																		CR(CM)=94 CR(%)=63 RQD(%)=20
190.631	9.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone										NX							CR(CM)=75 CR(%)=50 RQD(%)=16
189.131	10.50																		CR(CM)=103 CR(%)=69 RQD(%)=18
187.631	12.00											NX							CR(CM)=73 CR(%)=49 RQD(%)=19
186.131	13.50																		CR(CM)=61 CR(%)=41 RQD(%)=17
184.631	15.00																		



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banarpalli, Dist-Jharsugura, Odisha.

Coordinate: 1275 E, 1497 S RL: 199.631

Project No: 1988

Location: Boiler BH No. : 11 DEPTH : 25.00m Depth of Water Table : 1.10 m

Date of Start : 03/09/2013 Date of Finish : 21/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING mmNX BX AX	OTHER SIZES	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG													BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD				
184.631	15.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone				<10 mm size	10 to 25 mm	25 to 75 mm	75 to 150 mm	>150 mm						NO	20	40	60	80	CR(CM)=94 CR(%)=63 RQD(%)=26
183.131	16.50															NO	20	40	60	80	CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 5 cm 63 Blows
181.631	18.00	Highly weathered disintegrated Rock														NO	20	40	60	80	CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 Penetration 6 cm 71 Blows
180.131	19.50															NO	20	40	60	80	CR(CM)=18 CR(%)=12 RQD(%)=Nil
178.631	21.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone														NO	20	40	60	80	CR(CM)=22 CR(%)=15 RQD(%)=7
177.131	22.50															NO	20	40	60	80	CR(CM)=70 CR(%)=47 RQD(%)=35
175.631	24.00	Highly weathered and fractured Greyish color Shale														NO	20	40	60	80	CR(CM)=56 CR(%)=56 RQD(%)=34
174.631	25.00															NO	20	40	60	80	

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1295 E, 1552 S RL: 199.400 Project No: 1988

Location: ESP BH No. : 12 DEPTH : 20.00m Depth of Water Table : 0.75m

Date of Start : 05/10/2013 Date of Finish : 06/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)			Density (gm/cc)	W/C	Limits (%)	Sp.Gr	Shear Parameters			Cc
				Observed			Gravel	Sand	Silt/Clay				L.L	P.L	Type of test	C(kg/sq.cm)
199.400	0.00	SPT UDS	Filledup Soil (Soil)	 0.00 1.00 2.00 3.00 4.00 5.00 6.00 7.00 8.00 9.00 10.00 11.00 12.00												UU 1.26 3
197.600	1.80		Silty Clay mixed with sand (CL)	1	34	65	1.88	1.52	23.28					42	23	
196.900	2.50		Refusal Strata	1	25	74								43	23	
196.100	3.30			15 Cm, 80 Blows	83	100										
195.900	3.50															

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1295 E, 1552 S RL: 199.400

Project No: 1988

Location: ESP BH No. : 12 DEPTH : 20.00m Depth of Water Table :0.75m

Date of Start : 05/10/2013 Date of Finish : 06/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG										TEST SECTION	PRESSURE (kg/sq cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL	
195.900	3.50	Highly weathered highly fractured yellowish color Sandstone/siltstone				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=30 CR(%)=30 RQD(%)=Nil
194.900	4.50					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=68 CR(%)=45 RQD(%)=21
193.400	6.00					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=76 CR(%)=51 RQD(%)=25
191.900	7.50	Highly weathered and fractured yellowish color Sandstone/ siltstone				0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=54 CR(%)=36 RQD(%)=17
190.400	9.00					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=64 CR(%)=43 RQD(%)=11
188.900	10.50					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100	0 20 40 60 80 100						CR(CM)=69 CR(%)=46 RQD(%)=7
187.400	12.00					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100			0 20 40 60 80 100	0 20 40 60 80 100						

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1295 E, 1552 S RL: 199.400

Project No: 1988

Location: ESP BH No. : 12 DEPTH : 20.00m Depth of Water Table :0.75m

Date of Start : 05/10/2013 Date of Finish : 06/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING	OTHER SIZES	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS		
		< 10 mm size	10 to 25 mm	25 to 75 mm	75 to 150 mm	> 150 mm											TEST SECTION	PRESSURE (kg/sq cm)	LOSS (ml)	DEPTH OF WATER LEVEL	TIME INTERVAL		
187.400	12.00	Highly weathered highly fractured yellowish color Sandstone/ siltstone							0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100				0 20 40 60 80 100	0 20 40 60 80 100					CR(CM)=74 CR(%)=49 RQD(%)=Nil		
185.900	13.50																						CR(CM)=71 CR(%)=47 RQD(%)=10
184.400	15.00	Highly weathered and fractured yellowish color Sandstone/ siltstone																					CR(CM)=83 CR(%)=55 RQD(%)=38
182.900	16.50																						CR(CM)=69 CR(%)=46 RQD(%)=43
181.400	18.00																						CR(CM)=58 CR(%)=39 RQD(%)=17
179.900	19.50																						CR(CM)=27,CR(%)=54 RQD(%)=54
179.400	20.00																						

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Co ordinates : 1434E, 1639S RL 199.50

Project No: 1988

Location: ESP BH No. : 13 DEPTH : 20.00m Depth of Water Table 1.10m

Date of Start : 14/10/2013 Date of Finish : 17/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot			Grain size (%)			Density (gm/cc)	W/C	Limits (%)		Shear Parameters			Cc	
				Observed			Gravel	Sand	Silt/Clay			r(wet)	r(dry)	W(%)	L.L	P.L	Sp.Gr	Type of test
199.500	0.00		Filledup Soil (Road Material)															
197.700	1.80	SPT																
197.000	2.50	UDS																
196.200	3.30	SPT	Silty Clay mixed with sand (CL)															
194.700	4.80	SPT																
193.200	6.30	SPT	Refusal Strata															



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Co ordinates : 1434E, 1639S RL 199.50

Project No: 1988

Location: ESP BH No. : 13 DEPTH : 20.00m Depth of Water Table 1.10m

Date of Start : 14/10/2013 Date of Finish : 17/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	OTHER SIZES mm NX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG											TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL TIME INTERVAL	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD
193.50	6.00						0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=92, CR(%)=61 RQD(%)=21
192.00	7.50	Highly weathered and fractured yellowish color Sandstone/ Siltstone					0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=50 CR(%)=34 RQD(%)=10
190.50	9.00						0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=63 CR(%)=42 RQD(%)=33
189.00	10.50						0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100	NX		0 20 40 60 80 100							CR(CM)=78 CR(%)=52 RQD(%)=18
187.50	12.00																		



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Co ordinates : 1434E, 1639S RL 199.50

Project No: 1988

Location: ESP BH No. : 13 DEPTH : 20.00m Depth of Water Table 1.10m

Date of Start : 14/10/2013 Date of Finish : 17/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	OTHER SIZES	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS								
		DESCRIPTION	LOG												0	20	40	60	80	100	TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD				
																	PRESSURE (kg/sq.cm)	LOSS(l/m)	DEPTH OF WATER LEVEL	TIME INTERVAL							
187.50	12.00																										
186.00	13.50																										
184.50	15.00	Highly weathered Disintegrated Siltstone																									
183.00	16.50																										
181.50	18.00																										
180.00	19.50																										
179.50	20.00																										

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1468 E, 1556 S RL: 199.700 Project No: 1988

Location: ESP BH No. :14 DEPTH : 20.00m Depth of Water Table :0.60m

Date of Start : 08/10/2013 Date of Finish : 10/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)			Density (gm/cc)		W/C	Limits (%)	Sp.Gr	Shear Parameters			Cc								
				Observed																					
				0	20	40	60	80	100	120															
199.700	0.00		Filledup Soil (Soil Material)	0.00	1.00	2.00	3.00	4.00	5.00	6.00															
196.400	3.30	SPT	Silty Clay of medium Plasticity (Cl)	*34	0	30	70									38	19								
195.200	4.50	SPT	Refusal Strata	15 Cm, 67 Blows	1	8	91																		
				12.00																					



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1468 E, 1556 S RL: 199.700

Project No: 1988

Location: ESP BH No.: 14 DEPTH : 20.00m Depth of Water Table : 0.60m

Date of Start : 08/10/2013 Date of Finish : 10/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS						
		Size of core pieces											TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD								
		< 10 mm size	10 to 25 mm	25 to 75 mm	75 to 150 mm	> 150 mm							PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL TIME INTERVAL								
195.200	4.50	Highly weathered highly fractured greyish to yellowish color Sandstone/ Siltstone						NX								CR(CM)=22 CR(%)=15 RQD(%)=Nil							
193.700	6.00																						
192.200	7.50																						
190.700	9.00																						
189.200	10.50																						
187.700	12.00	Highly weathered and fractured brownish to yellowish color Sandstone/ Siltstone						NX								CR(CM)=56 CR(%)=37 RQD(%)=37							



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1468 E, 1556 S RL: 199.700

Project No: 1988

Location: ESP BH No. : 14 DEPTH : 20.00m Depth of Water Table : 0.60m

Date of Start : 08/10/2013 Date of Finish : 10/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS
		DESCRIPTION	LOG										TEST SECTION	BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD		
187.700	12.00	Highly weathered highly fractured yellowish color Sandstone/ Siltstone				0 20 40 60 80 100	0 20 40 60 80	400		mm NX BX AX	0 20 40 60 80 100	NO PARTIAL COMPLETE	PRESSURE (kg/sq.cm) LOSS(m)	DEPTH OF WATER LEVEL TIME INTERVAL			
186.200	13.50									NX							CR(CM)=62 CR(%)=41 RQD(%)=31
184.700	15.00									NX							CR(CM)=84 CR(%)=56 RQD(%)=35
183.200	16.50	Highly weathered and fractured greyish to yellowish color Sandstone/ Siltstone								NX							CR(CM)=85 CR(%)=57 RQD(%)=53
181.700	18.00									NX							CR(CM)=77 CR(%)=51 RQD(%)=41
180.200	19.50																CR(CM)=31, CR(%)=31 RQD(%)=12
179.700	20.00																

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1396 E, 1711S RL: 199.700 Project No: 1988

Location: Chimney BH No. : 16 DEPTH : 25.00m Depth of Water Table 1.20m Date of Start : 05/10/2013 Date of Finish : 06/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)			Density (gm/cc)	W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc										
				Observed						Gravel	Sand	Silt/Clay	r(wet)	r(dry)	W(%)	L.L	P.I	Type of test	C(kg/sqcm)	phi(degrees)					
199.700	0.00	SPT	Filledup Soil (Road Material mixed with soil)							0	20	40	60	80	100	120									
197.900	1.80									0.00	1.00	2.00	3.00	4.00	5.00	6.00	7.00	8.00	9.00	10.00	11.00	12.00			
196.400	3.30		Silty Clay of medium Plasticity (CL)							*28															
195.200	4.50									0	4	96													
193.400	6.30									0	3	97													
191.900	7.80		Sandy Silt (SM-ML)							1	6	94													
190.400 190.200	9.30 9.50									8.00	9.00	10.00	11.00	12.00	*90	15 Cm, 77 Blows	0	30	70						
			Refusal Strata																						



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1396 E, 1711S RL: 199.700

Project No: 1988

Location: Chimney BH No. : 16 DEPTH : 25.00m Depth of Water Table 1.20m

Date of Start : 05/10/2013 Date of Finish : 06/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	CASING	GROUT	OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST		PERMEABILITY	REMARKS			
		DESCRIPTION	LOG											BY APPLIED PRESSURE METHOD	BY FALLING HEAD METHOD					
190.200	9.50	Highly weathered highly fractured yellowish color Sandstone/Siltstone				0	20	40	60	80	100	0	20	NO	20	40	60	80	100	CR(CM)=15 CR(%)=10 RQD(%)=Nil N>100 10cm, 75 Blows
189.200	10.50					0	20	40	60	80	100	0	20	NO	20	40	60	80	100	CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 7 cm, 70 Blows
187.700	12.00	Highly weathered disintegrated Rock										NX								CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 5cm, 65 Blows
186.200	13.50	Highly weathered and fractured yellowish color Sandstone/Siltstone				0	20	40	60	80	100	0	20	NO	20	40	60	80	100	CR(CM)=27 CR(%)=18 RQD(%)=18
184.700	15.00	Highly weathered highly fractured yellowish color Sandstone/Siltstone				0	20	40	60	80	100	0	20	NO	20	40	60	80	100	CR(CM)=21 CR(%)=14 RQD(%)=Nil N>100 5cm, 71 Blows
183.200	16.50	Highly weathered and fractured yellowish color Sandstone/Siltstone				0	20	40	60	80	100	0	20	NO	20	40	60	80	100	CR(CM)=25 CR(%)=17 RQD(%)=17
181.700	18.00																			

BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1396 E, 1711S RL: 199.700

Project No: 1988

Location: Chimney BH No. : 16 DEPTH : 25.00m Depth of Water Table 1.20m

Date of Start : 05/10/2013 Date of Finish : 06/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mm NX BX AX	DEPTH OF WATER LEVEL	PERCOLATION TEST			PERMEABILITY	REMARKS		
		DESCRIPTION	LOG												TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(l/m)	DEPTH OF WATER LEVEL	TIME INTERVAL		
181.700	18.00	Highly weathered highly fractured yellowish color Sandstone/ Siltstone							0 20 40 60 80 100	0 20 40 60 80 100	mm			0 20 40 60 80 100					CR(CM)=18 CR(%)=12 RQD(%)=Nil N>100 4cm, 65 Blows		
180.200	19.50																				CR(CM)=13 CR(%)=9 RQD(%)=Nil N>100 5cm, 70 Blows
178.700	21.00	Highly weathered disintegrated Rock																			CR(CM)=Nil CR(%)=Nil RQD(%)=Nil N>100 7 cm, 77 Blows
177.200	22.50																				CR(CM)=32 CR(%)=21 RQD(%)=Nil
175.700	24.00	Highly weathered highly fractured yellowish color Sandstone/Siltstone																			CR(CM)=22 CR(%)=22 RQD(%)=Nil
174.700	25.00																				



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1358 E, 1072 S

RL: 199.436

Project No: 1988

Location: Switch Yard

BH No. : 32

DEPTH : 15.00m

Depth of Water Table : 0.80 m

Date of Start : 23/09/2013

Date of Finish : 24/09/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)		Density (gm/cc)		W/C		Limits (%)		Sp.Gr	Shear Parameters			Cc					
				Observed						Gravel	Sand	Silt/Clay	r(wet)	r(dry)	W(%)	L.L	P.L	Type of test	C(kg/sqcm)	phi(degrees)			
199.436	0.00	SPT	Filledup Soil (Soil with Ash)	0	20	40	60	80	100	120	0.00	1.00	2.00	3.00	4.00	5.00	6.00	7.00	8.00	9.00	10.00	11.00	12.00
197.636	1.80		Silty Clay mixed with sand (CL)	*10							13	34	33/20	1.81	1.45	24.89	36	19	UU	0.48	2	0.063	
196.936	2.50		UDS	*15							10	9	63/18										
196.136	3.30			5 Cm, 75 Blows							0	39	39/22										
194.936	4.50		Refusal Strata	*100																			



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1358 E, 1072 S RL: 199.436

Project No: 1988

Location: Switch Yard BH No.: 32 DEPTH : 15.00m Depth of Water Table : 0.80 m

Date of Start : 23/09/2013 Date of Finish : 24/09/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		Size of core pieces	STRUCTURAL CONDITIONS	DESCRIPTION	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mmNX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS	
		DESCRIPTION	LOG											TEST SECTION	PRESSURE (kg/sq.cm)	LOSS(m)	DEPTH OF WATER LEVEL	TIME INTERVAL	
194.936	4.50	Highly weathered highly fractured yellowish color Sandstone																CR(CM)=26 CR(%)=17 RQD(%)=12	
193.436	6.00	Highly weathered highly fractured yellowish color Sandstone																CR(CM)=78 CR(%)=52 RQD(%)=30	
191.936	7.50	Highly weathered highly fractured yellowish color Sandstone																CR(CM)=64 CR(%)=43 RQD(%)=Nil	
190.436	9.00																	CR(CM)=95 CR(%)=63 RQD(%)=27	
188.936	10.50																	CR(CM)=83 CR(%)=55 RQD(%)=39	
187.436	12.00	Highly to moderately weathered fractured yellowish color Sandstone																CR(CM)=112 CR(%)=75 RQD(%)=51	
185.936	13.50																	CR(CM)=138 CR(%)=92 RQD(%)=83	
184.436	15.00																		



BORE LOG

PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banhpalli, Dist-Jharsugura, Odisha.

Coordinate: 1432.500 E, 1196.00 S RL: 199.500 Project No: 1988

Location: Transformer Yard BH No. :34 DEPTH : 15.00m Depth of Water Table :0.40m Date of Start : 06/10/2013 Date of Finish : 07/10/2013

Reduced Level (m)	Depth (m)	Type of sample	Soil Classification	S.P.T Plot		Grain size (%)		Density (gm/cc)	W/C	Limits (%)	Sp.Gr	Shear Parameters		Cc		
				Observed		Gravel	Sand					r(wet)	r(dry)	L.L	P.L	
199.500	0.00	SPT	Filledup Soil (Soil mixed with Ash)	0.00	100											
197.700	1.80		Silty Sand with Gravel (SM)	1.00	*10											
197.000	2.50		UDS	2.00	*34											
196.200	3.30			3.00	*53											
195.000	4.50		Silty Clay mixed with Sand (CL-CH)	4.00												
193.200	6.30		SPT	5.00												
192.500	7.00			6.00	*67											
			Refusal Strata	7.00	*100*											
				8.00	10cm, 80 Blows											
				9.00												
				10.00												
				11.00												
				12.00												

BORE LOG



PROJECT: Geotechnical Investigation work for 2x660MW IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Coordinate: 1432.500 E, 1196.00 S RL: 199.500

Project No: 1988


Location: Transformer Yard BH No.:34 DEPTH : 15.00m Depth of Water Table :0.40m


Date of Start : 06/10/2013 Date of Finish : 07/10/2013

REDUCED LEVEL (m)	DEPTH (m)	LITHOLOGY		DESCRIPTION	LOG	Size of core pieces	STRUCTURAL CONDITIONS	PERCENT CORE RECOVERY	RQD	SIZE OF HOLE	GROUT	CASING OTHER SIZES mm NX BX AX	DEPTH OF WATER LEVEL	WATER LOSS	PERCOLATION TEST			PERMEABILITY	REMARKS												
		DESCRIPTION														BY APPLIED PRESSURE METHOD		BY FALLING HEAD METHOD													
		LOG	DESCRIPTION												PRESSURE (kg/sq.cm)	LOSS (ml/m)	DEPTH OF WATER LEVEL	TIME INTERVAL													
192.500	7.00							0 20 40 60 80 100	0 20 40 60 80 100	0 20 40 60 80 100				0 20 40 60 80 100					CR(CM)=18,CR(%)=36 RQD(%)=Nil												
192.000	7.50	Highly weathered and fractured yellowish color Sandstone/ Siltstone																		CR(CM)=54 CR(%)=36 RQD(%)=9											
190.500	9.00																			CR(CM)=60 CR(%)=40 RQD(%)=15											
189.000	10.50	Highly weathered highly fractured yellowish color Sandstone/ Siltstone																		CR(CM)=30 CR(%)=20 RQD(%)=Nil											
187.500	12.00	Highly weathered and fractured yellowish color Sandstone/ Siltstone																		CR(CM)=60 CR(%)=40 RQD(%)=16											
186.000	13.50	Highly weathered highly fractured yellowish color Sandstone/ Siltstone																		CR(CM)=53 CR(%)=35 RQD(%)=Nil											
184.500	15.00																														





SOIL PROFILE







EXPECTED SOIL PROFILE ALONG BH 3 to BH 5





EXPECTED SOIL PROFILE ALONG BH 8 & BH 9









GRAIN SIEVE ANALYSIS


GRAIN SIZE DRISTRIBUTION CURVE




GRAIN SIZE DRISTRIBUTION CURVE




GRAIN SIZE DISTRIBUTION CURVE




GRAIN SIZE DRISTRIBUTION CURVE




GRAIN SIZE DISTRIBUTION CURVE




GRAIN SIZE DRISTRIBUTION CURVE




GRAIN SIZE DISTRIBUTION CURVE




GRAIN SIZE DISTRIBUTION CURVE




GRAIN SIZE DRISTRIBUTION CURVE




GRAIN SIZE DISTRIBUTION CURVE







GRAIN SIZE DRISTRIBUTION CURVE




GRAIN SIZE DISTRIBUTION CURVE



GRAIN SIZE DISTRIBUTION CURVE




GRAIN SIZE DISTRIBUTION CURVE




PROJECT: Geotechnical Investigation work for proposed Structure at 2x660MW
IB Thermal Power Station, Unit-3 & 4, Banharpalli, Dist-Jharsugura, Odisha.

Fig : GSD-16

GRAIN SIZE DISTRIBUTION CURVE





GRAIN SIZE DRISTRIBUTION CURVE







DIRECT SHEAR TEST

BH-9
DEPTH = 2.50 m.




BH - 4
DEPTH = 2.50 m.








TRI-AXIAL TEST




TRIAXIAL TEST RESULTS









TRIAXIAL TEST RESULTS





TRIAXIAL TEST RESULTS



TRIAXIAL TEST RESULTS