



**BGR ENERGY SYSTEMS LTD.
POWER PROJECTS DIVISION**

BOP EPC CONTRACTOR DOCUMENT NO.
GID-208-CV-UPC-CA-3501

OWNERS DOCUMENT NO.

-

**SBC AND SETTLEMENT CALCULATION FOR GRANULAR/COHESIVE
NON SWELLING /MURRUM SOIL**

REV

0

**ODISHA POWER GENERATION CORPORATION LIMITED
2 X 660 MW IB THERMAL POWER STATION
BANHARPALLI, JHARSUGUDA, ODISHA-768234**

**SBC AND SETTLEMENT CALCULATION FOR GRANULAR/COHESIVE NON SWELLING /MURRUM
SOIL**

GID-208-CV-UPC-CA-3501



**BGR ENERGY SYSTEMS LIMITED
POWER PROJECTS DIVISION
443, ANNA SALAI
TEYNAMPET, CHENNAI - 600018
PH 044 24352436, FAX 044 24315678
E Mail – ppd@bgrenergy.com**

28.05.16	0	ISSUED FOR APPROVAL			
			GM	VSK	TVBSSM
DATE	REV	DESCRIPTION	PRPD	CHKD	APPD



BGR ENERGY SYSTEMS LTD

POWER PROJECTS DIVISION

PROJECT:

OPGCL - 2x660MW IB THERMAL POWER STATION, UNIT-3 & 4,
JHARSUGUDA, ODISHA.

TITLE :

SAFE BEARING CAPACITY AND SETTLEMENT CALCULATIONS FOR
GRANULAR / MURRUM/COHESIVE NON SWELLING SOILS

As per site condition

1) BEARING CAPACITY OF SOIL BASED ON SHEAR FAILURE CRITERIA (as per IS: 6403-1981)

Granular / Murrum / CNS material shall be used for replacement of loose soils/ash fill where encountered, compaction to 95%

Foundation resting on Non Plastic Strata,

The Ultimate net bearing capacity of soil can be obtained using the equation given below

$$Q_u = q (N_q - 1) S_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma w'$$

as per Cl. 5.2.2.1

Where,

q = Effective overburden pressure at foundation level in t/m²

B = Width of footing in m

γ = Bulk unit of soil in t/m³

N_q, N_γ = Bearing capacity factors as per table-1

S_q, S_γ = Shape factors as per table-2

d_q, d_γ = Depth factors as per Cl 5.1.2.2

i_q, i_γ = Inclination factors as per Cl 5.1.2.3

W' = Water table correction factor as per Cl 5.1.2.4

Input data

B = 2.0 Width of footing in m

L = 2.0 Length of footing in m

D_f = 2.0 Depth of footing in m

D_w = 0.0 Depth of ground water table in m

γ = 1.8 Bulk unit of soil in t/m³

γ' = 0.8 Submerged unit of soil in t/m³

Φ = 33 Angle of shearing resistance of soil in degrees

W' = 0.5 Water table correction factor

FoS = 2.5 Factor of safety

For $\Phi' = 25$	For square shape	d-factors	i-factors
$N_q = 10.66$	$S_q = 1.2$	$d_q = 1.0$	$i_q = 1.0$
$N_\gamma = 10.88$	$S_\gamma = 0.8$	$d_\gamma = 1.0$	$i_\gamma = 1.0$

Ultimate Bearing Capacity

$$\begin{aligned}
 Q_{ulti} &= q (N_q - 1) S_q d_q i_q + 0.5 B \gamma N_\gamma s_\gamma d_\gamma i_\gamma w' \\
 &= 27 \quad \text{t/m}^2
 \end{aligned}$$

Safe Bearing Capacity using factor of safety of 2.5

$$Q_{safe} = 11 \quad \text{t/m}^2$$



BGR ENERGY SYSTEMS LTD

POWER PROJECTS DIVISION

PROJECT:

OPGCL - 2x660MW IB THERMAL POWER STATION, UNIT-3 & 4,
JHARSUGUDA, ODISHA.

TITLE :

SAFE BEARING CAPACITY AND SETTLEMENT CALCULATIONS FOR
GRANULAR / MURRUM/COHESIVE NON SWELLING SOILS

2) BEARING CAPACITY OF SOIL BASED ON SETTLEMENT CRITERIA (as per IS: 8009(Part 1) - 1976)

The Imposed load at foundation level is likely to compress the soil below and depth of influence shall be upto a depth of 1.5B. The Settlements can be calculated using Figure 9 for given width of footing and SPT-N values.

$$D = 2.0$$

$$L = 2.0$$

$$B = 2.0$$

$$\frac{D}{\sqrt{L \times B}} = 1.0$$

$$\frac{L}{B} = 1.0$$

Sf - depth correction factor from Fig 12

Df (RL of Foundation depth in m)	Df @ RL
B (Width of foundation depth in m)	2 m
Settlement under footing with a load intensity of 10 t/m ² in dry condition	14.0 mm
Settlement under footing with a load intensity of 10 t/m ² with water correction	28.0 mm
Settlement under footing with a load intensity of 10 t/m ² with water and depth correction	24.4 mm
Net safe bearing pressure for allowable settlement of 25mm	10 t/m²

3) Recommendations.

The net safe bearing pressure of **10 t/m²** is recommended for design.